

COUNTY OF HARNETT  
Building Inspections Department  
Planning Services

**Certificate of Compliance:** \_\_\_\_\_ **Occupancy:** ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Randy Szczublewski

Address: 145 Jimmy Dr

\_\_\_\_\_

\_\_\_\_\_

Date: 1-30-18

**Permit Numbers**

Building: \_\_\_\_\_

Electrical: \_\_\_\_\_

Insulation: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Mechanical: \_\_\_\_\_

MFG Home: 17-500 42750

Building Official: James Hall

ADDRESS . . : 145 JIMMY DR SUBDIV:  
TENANT, NBR: 1850043180 - TEMP RV REF#  
CONTRACTOR : STATE MOBILE HOME MOVERS PHONE : (910) 894-8038  
OWNER . . : SZCZUBLEWSKI RANDY & LORI PHONE :  
PARCEL . . : 12-0556- - -0140- -03-  
APPL NUMBER: 17-50042750 CP MANUFACTURED HOME RA20R/RA20M CRITERIA  
DIRECTIONS : T/S: 11/14/2017 10:44 AM LLUCAS ----  
TAKE 401 TOWARDS FAYETTEVILLE - TURN  
RIGHT ON MCLEAN CHAPEL CHURCH RD - TURN  
LEFT ON WIRE RD - TURN RIGHT ON JIMMY  
DR

**STRUCTURE: 000 000 28X56 DWMH 3BDR 2BTH**

FLOOD ZONE . . . . : FLOOD ZONE X  
# BATHS . . . . . : 2 # BEDROOMS . . . . . : 3.00  
MOBILE HOME YEAR . . . . : 2017.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : EXIST WATER SUPPLY . . . . . : COUNTY

**PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	1/19/18 1/19/18	JH DA	R*MOBILE HOME FOUND./ M. WALL VRU #: 003077310 1)Bond frame per code.2)DWV test froze.3)Hole under house full of water need to drain and cover with plastic.4)Cover all holes in belly board under house.5)Cover water line cross over with a box like electrical cross over.
T501 02	1/23/18 1/23/18	JH DP	R*MOBILE HOME FOUND./ M. WALL VRU #: 003078532 ITEMS #3 & 5 not corrected
A814 01	1/24/18 1/24/18	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003079233 145 JIMMY DR BUNNLEVEL 2832 145 JIMMY DR BUNNLEVEL 28323
T501 03	1/24/18 1/24/18	JH AP	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 003079225 T/S: 01/23/2018 12:08 PM DJOHNSON ----- SCHEDULED FOR MICHELLE.
Z818 01	1/29/18 1/29/18	AD AP	PZ*ZONING INSPECTION VRU #: 003081171 T/S: 01/29/2018 11:37 AM LLUCAS -----
T507 01	1/30/18 <i>1-30-18 AP JH</i>	TI	R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 003082344 T/S: 01/29/2018 11:38 AM LLUCAS -----

----- COMMENTS AND NOTES -----