



North Carolina State Laboratory of Public Health
Environmental Sciences
Inorganic Chemistry

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

Certificate of Analysis

FINAL REPORT

Report to: OLIVER TOLKSDORF

Name of System:

HARNETT CO ENVIRONMENTAL HEALTH
 307 CORNELIUS HARNETT BLVD
 LILLINGTON, NC 27546

Mark Farnsworth
 2782 Norrington Rd
 Lillington, NC 27546

EIN: 566000306EH

Delivery: NC Courier

StarLiMS ID: **ES191024-0056**

Date Collected: 10/23/2019

Time Collected: 10:17

By: Oliver Tolksdorf

Date Received: 10/24/2019

Time Received: 07:49

Sample Type: Raw

Sampling Point: Spigot at well

Well Permit No.

Sample Source: New Well

Receipt Temp.: 1.7 °C

GPS Number:

Comment: No permit # given with sample.

Profile: New Well I

Analyte	Test Result	Allowable Limit	Unit	Qualifier(s)
Arsenic	<0.005	0.010	mg/L	
Barium	0.30	2.0	mg/L	
Cadmium	<0.001	0.005	mg/L	
Calcium	27		mg/L	
Chloride	<5	250	mg/L	
Chromium	<0.01	0.10	mg/L	
Copper	<0.05	1.3	mg/L	
Fluoride	<0.2	4	mg/L	
Iron	2.36	0.30	mg/L	
Lead	<0.005	0.015	mg/L	
Magnesium	12		mg/L	
Manganese	0.20	0.05	mg/L	
Mercury	<0.0005	0.002	mg/L	
Nitrate	<1	10.0	mg/L	
Nitrite	<0.1	1.00	mg/L	
pH	7.7		N/A	
Selenium	<0.005	0.05	mg/L	
Silver	<0.05	0.10	mg/L	
Sodium	12.5		mg/L	
Sulfate	5.4	250	mg/L	
Total Alkalinity	129		mg/L	
Total Hardness	115		mg/L	
Zinc	2.18	5.00	mg/L	



North Carolina State Laboratory of Public Health
Environmental Sciences
Inorganic Chemistry

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Certificate of Analysis

FINAL REPORT

Report Date: 11/21/2019

Reported By:

A handwritten signature in black ink, appearing to read "Marc Komlos".

Marc Komlos



Private Well Information and Use Recommendations

For Inorganic Chemical Contaminants

County:

Name:

Sample ID #:

Reviewer:

TEST RESULTS AND USE RECOMMENDATIONS

1. Your well water meets federal drinking water standards *for inorganic chemicals*. Your water can be used for drinking, cooking, washing, cleaning, bathing, and showering based on the ***inorganic chemical results only***. You may have other water sampling results that are not taken into account in this report.
2. The following substance(s) exceeded federal drinking water standards or the North Carolina 2L calculated health levels. The North Carolina Division of Public Health recommends that your well water not be used for drinking and cooking, unless you install a water treatment system to remove the circled substance(s). However, it may be used for washing, cleaning, bathing and showering based on the ***inorganic chemical results only***.

Arsenic	Barium	Cadmium	Chromium	Copper	Fluoride	Lead	Iron	
Manganese	Mercury	Nitrate/Nitrite	Selenium	Silver	Magnesium	Zinc	pH	

3. a. Sodium levels exceed the U.S. Environmental Protection Agency's (USEPA) Health Advisory level for sodium of 20 mg/l. The North Carolina Division of Public Health recommends that only individuals on no or low sodium restricted diets not use this water for drinking or cooking. It may be used for washing, cleaning, bathing, and showering based on the ***inorganic chemical results only***.
- b. Levels over 30 mg/l may pose aesthetic problems such as bad taste, odor, staining of porcelain, etc.
4. Re-sampling is recommended in _____ months.
5. Re-sample for lead and /or copper. Take a first draw, 5 minute, and 15 minute sample inside the house (preferably the kitchen) and if possible a first draw, 5 minute and a 15 minute sample at the well head to determine the source of the lead and/or copper.
6. The following substance(s) exceeded federal drinking water standards. Your water can be used for drinking, cooking, washing, cleaning, bathing, and showering based on the ***inorganic chemical results only***, but aesthetic problems such as bad taste, odor, staining of porcelain, etc. may occur. You may want to install a household water treatment system to address aesthetic problems.

Barium	Cadmium	Chromium	Fluoride	Iron	Magnesium
Manganese	Selenium	Silver	pH	Zinc	

For more information regarding your well water results, please call the North Carolina Division of Public Health at 919-707-5900.