

ADDRESS : 1118 DARROCH RD SUBDIV: JOSEPH M BROWN & LISA M BROWN  
CONTRACTOR : PHONE :  
OWNER : BAREFOOT, JOHN G & ANNIE R PHONE : (910) 425-6697  
PARCEL : 01-0536- - -0012- - -  
APPL NUMBER: 18-50043809 CP MANUFACTURED HOME RA20R/RA20M CRITERIA  
DIRECTIONS : T/S: 04/16/2018 10:58 AM BPETRICH --  
1118 DARROCH ROAD LILLINGTON 27546  
LOT IS AT CORNER OF DARROCH AND FRED  
MCARTAN LANE.

(910) 366-7776

STRUCTURE: 000 000 28X48 3BD 3BA DWMH

FLOOD ZONE : FLOOD ZONE X  
# BATHS : 2 # BEDROOMS : 3.00  
MOBILE HOME YEAR : 1995.00 PROPOSED USE : DWMH  
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	5/02/18 5/03/18	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 003121795 1118 DARROCH RD LILLINGTON 27546 T/S: 05/03/2018 04:12 PM SBENNETT -----
T501 01	5/02/18 5/02/18	JH DA	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 003121787 T/S: 05/01/2018 11:30 AM BPETRICH ----- 1)Insulate water lines per code.2)Need prv on water line.3)Repair all tears on belly board under home.4)Support drain lines every 4' per code.5)Crossover duct under house needs to be 4" from ground. OK TO COVER ENDS AND CONNECT DRAIN LINE TO TANK.
T501 02	5/15/18 5/15/18	JH AP	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 003127487 T/S: 05/14/2018 11:58 AM DJOHNSON -----
Z818 01	7/03/18 <u>7/03/18</u>	TI <u>R.B./AP</u>	PZ*ZONING INSPECTION TIME: 17:00 VRU #: 003146834 T/S: 07/02/2018 08:59 AM BPETRICH -----

COMMENTS AND NOTES