

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: *Sewer* Design Flow (.1949): *360 gpd* Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<i>LS 5-7</i>	<i>0-21</i>	<i>G LS</i>	<i>VF2 NS/HP</i>					
		<i>21-36^{11"}</i>	<i>SBK C</i>	<i>F2 SS/SP</i>	<i>10/27/2e 36"</i>				<i>PS .35</i>
2		<i>0-22</i>	<i>G LS</i>	<i>VF2 NS/HP</i>					
		<i>22-38^{11"}</i>	<i>SBK C</i>	<i>F2 SS/SP</i>	<i>10/27/2e 36"</i>				<i>PS .35</i>

Description	Initial System	Repair System	Other Factors (.1946): <i>PS</i> Site Classification (.1948): Evaluated By: <i>OT</i> Others Present: <i>Mr. Goy</i>
Available Space (.1945)	<i>✓</i>	<i>✓</i>	
System Type(s)	<i>AS 2/2R</i>		
Site LTAR	<i>.35</i>	<i>.35</i>	