

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940										
SLOPE (%)	.1940										
HORIZON 1 DEPTH		0-18	0-28	0-24							
Texture Group	.1941(A)(1)	S	S	S							
Consistence	.1941	✓	✓	✓							
Structure	.1941(A)(2)	C	G	G							
Mineralogy	.1941(A)(3)	NOP	NEV	NOP							
HORIZON 2 DEPTH		18-24	28-32	24-28							
Texture Group	.1941(A)(1)	SC	Sq	SC							
Consistence	.1941	✓	✓	✓							
Structure	.1941(A)(2)	SB	SB	SB							
Mineralogy	.1941(A)(3)	SO	SO	SO							
HORIZON 3 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
HORIZON 4 DEPTH											
Texture Group	.1941(A)(1)										
Consistence	.1941										
Structure	.1941(A)(2)										
Mineralogy	.1941(A)(3)										
SOIL WETNESS	.1942										
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/.1956										
CLASSIFICATION	.1948	PS	PS	PS							
LONG TERM ACCEPTANCE RATE	.1955	.5	.5	.5							

②

③




	Minimum	Actual
Front	<u>35</u>	<u>881</u>
Side	<u>10</u>	<u>35</u>
Corner	<u>20</u>	
Rear	<u>25</u>	<u>946</u>
Nearest Building	<u>10</u>	<u>298</u>


DISTRICT RA-3D USE DWMH

#BEDROOMS 4

Date _____

Zoning Administrator





4x80
18-20