


Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

☐ Repairs      ☒ Nitrification Line

Distance From Well: \_\_\_\_\_ ft.

French Drain Required: 1 Linear feet

Signed: James C. Manhart DRS  
Environmental Health Specialist



#03-5-6633

# HARNETT COUNTY HEALTH DEPARTMENT AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department, Improvement Permit # 19959. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Name ANGELINE R LEWIS Telephone# 919-665-3648  
Address 291 Fletcher Tutor Rd Holly Springs N.C. 27540  
Property Location SR# 1406 Road Name Fletcher Tutor Rd  
Subdivision Fredrick C Way staff Lot # 6 # Bedrooms Proposed 3 Lot Size 4.55

## TYPE OF SYSTEM

☒ New Installation ☐ Repair ☒ Septic Tank ☐ Nitrification Lines

☒ Conventional ☐ Other \_\_\_\_\_

☐ Basement ☐ With Plumbing ☐ Without Plumbing

Water Supply: ☒ Well ☐ Public Water Supply Minimum Well Setback: 50 Ft.

Septic Tank 1000 gal Pump Chamber \_\_\_\_\_ gal

## NITRIFICATION FIELD SPECIFICATIONS

Number of fields 2 # of lines per field 3 Length of lines 70 Ft.

Width of ditches 3 ft. Depth of ditches 18-24 inches

French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

James C. Monahan  
Signature of Authorized Agent for Harnett County of Harnett

3-25-03  
Date