

IMPROVEMENT PERMIT

20968

HTE 04-5-10048

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Jeremy Byrd

New Installation

Septic Tank

Property Location: SR# 2007 Clayale

Repairs

Nitrification Line

Subdivision _____ Lot # _____

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 4 Lot Size: 1 mu

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons


Subsurface Drainage Field No. of ditches 5 exact length of each ditch 80 ft. width of ditches 3 ft. depth of ditches 18-20 in.

French Drain Required: - Linear feet

Date: 8-12-04

This permit is subject to revocation if site plans or intended use change.

Signed: James E. Markant
Environmental Health Specialist



04-5-10048

HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 20968. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

Name Jeremy Byrd Telephone # 910-897-8372

Address P.O. Box 311 Coats N.C. 27521

Property Location SR# 2007 Road Name Clayhole

Subdivision _____ Lot # 1 # Bedrooms Proposed 4 Lot Size 1 acre

TYPE OF SYSTEM

New Installation Repair Septic Tank Nitrification Lines

Conventional Other _____

Basement With Plumbing Without Plumbing

Water Supply: Well Public Water Supply Minimum Well Setback: _____ Ft.

Septic Tank 1000 gal Pump Chamber _____ gal

NITRIFICATION FIELD SPECIFICATIONS

Number of fields 2 # of lines per field 5 Length of lines 80 Ft.

Width of ditches 3 ft. Depth of ditches 18-20 inches

French Drain: Linear feet required _____ Depth of gravel 1

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

James E. Monahan
Signature of Authorized Agent for Harnett County

8-12-04
Date

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Address:

Applicant:

Proposed Facility:

Design Flow (.1949):

Date Evaluated:

Location of Site:

Property Size:

Water Supply:

Public Individual Well

Property Recorded:

Evaluation Method:

Auger Boring Pit Spring Other

Type of Wastewater:

Sewage Industrial Process Cut Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR	
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz		
1	L	0-12	SL	FR GR NSNP					.4	
		12-36	SL	FR GR NSNP	34					
2	L	0-14	SL	FR GR NSNP					.4	
		14-36	SL	FR GR NSNP	34					

Description	Initial System	Repair System
available Space (.1945)	/	/
ystem Type(s)	/	/
te LTAR	.4	.4

Other Factors (.1946): _____
 Site Classification (.1948): _____
 Evaluated By: _____
 Others Present: _____

Ralph O. Byrd (13.50 Acres)
Deed Book 707, Page 933


SITE PLAN APPROVAL

DISTRICT R430 USE DWMH

#BEDROOMS 4

Date 8/2/04 Prussell
Zoning Administrator

SUB 18' max



↑ To Clay Hider Rd (#2007)

Joseph Paul Johnson
Edward L. Johnson
Deed Book 1074, Page 6A

DEED REFERENCE: Deed Book 1956, Page 174-177

STATE OF NORTH CAROLINA
 COUNTY OF ...
 This Deed was presented to the Register and recorded
 in his office of Map number ...
 the ... day of ...
 at ...
 in the year of our Lord one thousand nine hundred and ...
 and of the Independence of the United States the ...
 and of the ...

1=100