

HTE 0450010643

IMPROVEMENT PERMIT

21675

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) CHRISTY PATTERSON New Installation Septic Tank
 Property Location: SR# 1130 NORRINGTON RD (MACK RD) Repairs Nitrification Line

Subdivision MCNEILL ACRES Lot # 11

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 4 Lot Size: .94 AC

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other PUMP TO 25% REDUCTION SYSTEM

Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Subsurface Drainage Field No. of ditches 6 exact length of each ditch 70 ft. width of ditches 3 ft. depth of ditches 12-14 in. ^{max}


French Drain Required: _____ Linear feet

Date: 2/21/05

Signed: [Signature] RS (OLIVER TOLKSDORF)
 Environmental Health Specialist

This permit is subject to revocation if site plans or intended use change.

- * MAINTAIN ALL SETBACKS
- * PUMP SPECS
45gpm @ 20' TDH
- * MANATEE SPECS
2' PRESSURE HEAD
2" SCH 40 PIPE
6 1/8" SCH 40 VALVES
- * MINIMUM OF 6" OF COVER NEEDED OVER DRAINFIELD
- * CALL WITH ANY QUESTIONS PRIOR TO INSTALLATION



HARNETT COUNTY DEPARTMENT OF PUBLIC HEALTH
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Department of Public Health, Improvement Permit # 21675. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. *This authorization will be invalid if ownership, site plans, or intended use change.*

CHRISTY PATTERSON 910-814-1838
Name Telephone #

3445 US421 LILLINGTON NC 27546
Address

1130 NORRINGTON Rd
Property Location SR# Road Name

MCNEILL ACRES 11 4 .92 AC
Subdivision Lot # # Bedrooms Proposed Lot Size

TYPE OF SYSTEM

New Installation Repair Septic Tank Nitrification Lines

Conventional Other PUMP TO 2.5% REDUCTION SYSTEM

Basement With Plumbing Without Plumbing

Water Supply: Well Public Water Supply Minimum Well Setback: 100 Ft.

Septic Tank 1000 gal Pump Chamber 1000 gal

NITRIFICATION FIELD SPECIFICATIONS

Number of fields 1 # of lines per field 6 Length of lines 70 Ft.

Width of ditches 3 ft. Depth of ditches 12-14 inches ^{MAX!}

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the Improvement Permit and that a valid Operations Permit has been issued.

[Signature] 25 2/21/05
Signature of Authorized Agent for Harnett County Date