

HTE# 06-5-15806RR

Har... County Department of Public Health

24011

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: SR-1553 LIVE OAK ROAD

ISSUED TO: DON JEWELL - THE HOUSING CENTER

SUBDIVISION: MJR - Jimmy Johnson

LOT # 344

NEW REPAIR EXPANSION

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: DW MH

Proposed Wastewater System Type: 25% REDUCTION SYSTEM

Projected Daily Flow: 480 GPD

Number of bedrooms: 4 Number of Occupants: 8 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well _____ feet

Permit valid for: Five years

Permit conditions: _____ No expiration

Authorized State Agent: James E. Markerters

Date: 12-11-06

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: DON Jewell - THE HOUSING CENTER

PROPERTY LOCATION: SR 1553 LIVE OAK ROAD

SUBDIVISION: JIMMY JOHNSON

LOT # 344

Facility Type: DW MH New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 480 GPD

(See note below, if applicable 25% REDUCTION SYSTEM (Repair)

Installation Requirements/Conditions

Septic Tank Size 1200 gallons

Exact length of each trench 4 X 80 feet

Trench Spacing: 9 Feet on Center

Pump Tank Size _____ gallons

Trenches shall be installed on contour at a Maximum Trench Depth of: 24 inches

Soil Cover: 6 inches (Maximum soil cover shall not exceed 36" above the trench bottom)

(Trench bottoms shall be level to +/- 1/4" in all directions)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: 6 inches below pipe 2 inches above pipe

Conditions: _____

12 inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Markerters

Date: 12-11-06

Construction Authorization Expiration Date: 12-11-11

HTE# 06-5-15806 RR

Permit # 24011

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATION: 51553 LEWIS OAK

ISSUED TO: DON JEWELL - THE HARBING CENTER

SUBDIVISION: MTC - Jimmy Johnson

LOT # 344

Authorized State Agent: James E. Marshall

Date: 12-11-06

