

**Improvement Permit**

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Clyde Patterson PROPERTY LOCATION: 1274  
NEW ☒ REPAIR ☐ EXPANSION ☐ SUBDIVISION: JHA LOT # 3  
Type of Structure: MH 28x48 3BR Site Improvements required prior to Construction Authorization Issuance: \_\_\_\_\_  
Proposed Wastewater System Type: 25% Reduction System  
Projected Daily Flow: 360 GPD  
Number of bedrooms: 3 Number of Occupants: 6 max  
Basement ☐ Yes ☒ No  
Pump Required: ☐ Yes ☒ No ☐ May be required based on final location and elevations of facilities  
Type of Water Supply: ☐ Community ☒ Public ☐ Well Distance from well \_\_\_\_\_ feet Permit valid for: ☒ Five years  
Permit conditions: Meet on site for Final Layout maintain all set Back ☐ No expiration  
18" max Ditch Depth

Authorized State Agent: J. W. AR Date: 03-07-07 SEE ATTACHED SITE SKETCH  
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

**Construction Authorization**

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Clyde Patterson PROPERTY LOCATION: 1274  
SUBDIVISION: JHA LOT # 3  
Facility Type: MH 28x48 3BR ☒ New ☐ Expansion ☐ Repair  
Basement? ☐ Yes ☒ No Basement Fixtures? ☐ Yes ☐ No  
Type of Wastewater System\*\* 25% Reduction sys. (Initial) Wastewater Flow: 360 GPD  
(See note below, if applicable) 25% Reduction system (Repair)

**Installation Requirements/Conditions**

Septic Tank Size 1000 gallons Exact length of each trench 1x300 feet Trench Spacing: 9 Feet on Center  
Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6 inches  
Maximum Trench Depth of: \_\_\_\_\_ inches (Maximum soil cover shall not exceed 36" above the trench bottom)  
(Trench bottoms shall be level to  $\pm 1/4"$  in all directions)  
Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM Aggregate Depth: \_\_\_\_\_ inches below pipe  
Conditions: \_\_\_\_\_ inches above pipe  
\_\_\_\_\_ inches total

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: J. W. AR Date: 02-07-07 SEE ATTACHED SITE SKETCHConstruction Authorization Expiration Date: 03-07-2012

HTE# 07-500 | 6856 R


Permit # 23692

# Harnett County Department of Public Health Site Sketch

ISSUED TO: Clyde Patterson PROPERTY LOCATOR: 1274  
SUBDIVISION SHA LOT # 3  
Authorized State Agent: J. W. [Signature] Date: 07-27-27  
224'

Date: \_\_\_\_\_

Date: 07-07-07



STUB out Plumbing shallow where shown  
maintain all set backs

Install 1x300 & 25% Reduction system At 18" max ditch depth