

HTE# 08-500-20338

Harnett County Department of Public Health

24878

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Clyde Patterson
PROPERTY LOCATION: Thomas Farm Rd
SUBDIVISION: LBC LOT # 2
Type of Structure: MH 28x60-3BR
Proposed Wastewater System Type: Gravel
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement: No
Pump Required: No
Type of Water Supply: Public
Permit conditions: Meet with for final layout - maintain all set backs

Authorized State Agent: J. W. ... Date: 6-30-08
SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met.

ISSUED TO: Clyde Patterson
PROPERTY LOCATION: Thomas Farm Rd
SUBDIVISION: LBC LOT # 2
Facility Type: MH 28x60-3BR New
Basement? No
Type of Wastewater System: Gravel
(Initial) Wastewater Flow: 360 GPD
25% Reduction Sys (Repair)

Installation Requirements/Conditions
Septic Tank Size: 1000 gallons
Pump Tank Size: ... gallons
Number of trenches: 4
Exact length of each trench: 480 feet
Trench Spacing: 9 Feet on Center
Soil Cover: 6 inches
Maximum Trench Depth: 18 inches
Pump Requirements: ... ft. TDH vs. ... GPM
Aggregate Depth: ... inches below pipe, ... inches above pipe, ... inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
Owner/Legal Representative Signature: ... Date: ...

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes.
Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.
SEE ATTACHED SITE SKETCH
Authorized State Agent: J. W. ... Date: 06-30-08
Construction Authorization Expiration Date: 06-30-2013

HTE# 08-500-20338

Permit # 24878

Harnett County Department of Public Health Site Sketch

ISSUED TO: Clyde Patterson

PROPERTY LOCATOR: Thomas Farm Rd

SUBDIVISION LBC

LOT # 2

Authorized State Agent: Qu LAR

Date: 06-30-08

