

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:
 Address:
 Proposed Facility:
 Location of Site:
 Water Supply: Public Individual Well
 Evaluation Method: Auger Boring Pit
 Type of Wastewater: Sewage Industrial Process

Applicant:
 Date Evaluated: 4/16/02
 Property Size:
 Property Recorded: Spring Other
 Cut
 Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Saprot Class	.1944 Restr. Horiz.	
LS 3-676		0-12	G/LS	VFr MSNP					SS/PS.4
		12-25	SBR/C*	Fr SS SP	10YR 8/2 26"				
		0-15	G/L	VFr MSNP					PS.4
		15-31	SBR/C*	Fr SS SP					
		0-6	G/LS	VFr MSNP					SS/PS.4
		6-31	SBR/C*	Fr SS SP	10YR 8/2 26"				
		0-15	G/LS	VFr MSNP					PS.4
		15-31	SBR/CA	Fr SS SP					

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	Shallow flow	pump out
Site LTAR	4	14

Other Factors (.1946):
 Site Classification (.1948): PS
 Evaluated By: [Signature]
 Others Present: