

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: JAMES + LISA JEANEGAN
PROPERTY LOCATION: SK-1561 BAILEY RD
NEW [x] REPAIR [] EXPANSION []
Type of Structure: MOVED HOME
Proposed Wastewater System Type: Conventional 'Only'
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement [] Yes [x] No
Pump Required: [] Yes [] No [x] May be required based on final location and elevations of facilities
Type of Water Supply: [] Community [] Public [x] Well Distance from well 100 feet
Permit conditions: NO 25% REDUCTION - Conventional Only 12" max DITCH depth

Authorized State Agent: James E. Markant Date: 4-9-10
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: James + Lisa Jeanegan
PROPERTY LOCATION: SK1561 BAILEY RD
Facility Type: Moved Home [x] New [] Expansion [] Repair []
Basement? [] Yes [x] No Basement Fixtures? [] Yes [x] No
Type of Wastewater System: Conventional (ULTRA SHALLOW) MANHOLE (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable [])
Conventional (ULTRA SHALLOW) (Repair) 3-1/2" sch 40 valves
Installation Requirements/Conditions
Septic Tank Size 1000 gallons Exact length of each trench 160 feet Trench Spacing: 9 Feet on Center
Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6 inches ADDED
Maximum Trench Depth of: 12" max inches (Maximum soil cover shall not exceed 36" above the trench bottom)
Pump Requirements: ft. TDH vs. GPM Aggregate Depth: 6 inches below pipe 2 inches above pipe
Conditions: NO 25% REDUCTION - Conventional only 12" max DITCH depths 12 inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: Date:

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Markant Date: 4-9-10
Construction Authorization Expiration Date: 4-9-15

HTE# 10-5-24086

Permit # 25736

Harnett County Department of Public Health Site Sketch

ISSUED TO: JAMES + LISA JEWELL PROPERTY LOCATOR: 521561 Bailey RD
SUBDIVISION _____ LOT # _____

Authorized State Agent: JAMES E. MANKANT @ RAAS Date: 4-9-10
521561 Bailey RD

* Conventional (GRAVEL SYSTEM) ONLY 12" MAX DITCH.
NO 25% REDUCTION (ACCEPTED) ALLOWED.
AS DISCUSSED WITH OWNER.

- * System Flagged on site for NITRIFICATION LINES
- * STUB Plumbing OUT ABOVE grade or pump with BE Required,
- * 6" of fill MAXIMUM Required OVER LINES
- * WATER LINE 10' off Septic tank + Power LINE TO BE INSTALLED AS PERMITTED.

