

HTE# 10-5-24530

Harnett County Department of Public Health

26054

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Crystal Baker PROPERTY LOCATION: SR 1403 Cokesburg RD
 NEW REPAIR EXPANSION SUBDIVISION: Charles A Baker LOT # 1
 Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: DWMH
 Proposed Wastewater System Type: 25% REDUCTION (Accepted)
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 No expiration
 Permit conditions: _____

Authorized State Agent: James E. Marshall III REHS Date: 6-9-10 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Crystal Baker PROPERTY LOCATION: SR 1403 Cokesburg RD
 SUBDIVISION: Charles A Baker LOT # 1

Facility Type: DWMH New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% REDUCTION System (Accepted) (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable)
25% REDUCTION System Manholes (Repair)

Installation Requirements/Conditions
 Septic Tank Size 1000 gallons Exact length of each trench 240 feet Trench Spacing: 7 Feet on Center
 Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
 Maximum Trench Depth of: 28-18 inches (Maximum soil cover shall not exceed
 (Trench bottoms shall be level to +/- 1/4" 36" above the trench bottom)
 in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe
2 inches above pipe
 Conditions: _____ 12 inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Marshall III REHS Date: 6-9-10
 Construction Authorization Expiration Date: 6-9-15

HTE# 10-5-24530

Permit # 26054

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATOR: JR 1403 Cokesbury RD

ISSUED TO: Crystal Baker SUBDIVISION Charles A Baker LOT # 1

Authorized State Agent: James E. Monkant Date: 6-9-10

