

**SOIL/SITE EVALUATION**  
 for ON-SITE WASTEWATER SYSTEM

Owner: Applicant: 24765 7-  
 Address: Date Evaluated: 8-2-3-4-10  
 Proposed Facility: DWMCA Design Flow (.1949): 600  
 Location of Site: Property Recorded:  
 Water Supply:  Public  Individual  Well  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

Property Size:  
 Spring  Other

PROFILE #	.1940 Landscape Position/Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 5%	0-48	SL	FL GRNSNP					7-2.8
2	L 5%	0-24	SL	FL GRNSNP					
		24-32	SC-CL	FL GRNSNP	ROCKS AT 32				4-3.5
3	L 5%	0-22	SL	FL GRNSNP					
		22-36	SC-CL	FL GRNSNP	34" rocks				3.5
4	L 3%	0-32	SL	FL GRNSNP					
		32-44	SL	FL GRNSNP	42" 7.5% 4.2				4
5	L 3%	0-26	SL	FL GRNSNP					
		26-48	SC-CL	FL GRNSNP	44-48 7.5% 4.2				4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): 75 Evaluated By: [Signature] Others Present:
Available Space (.1943)	✓	✓	
System Type(s)	26" w	26" w	
Site LTAR	4	4	