

HTE# 10-5-25817

Harnett County Department of Public Health

Improvement Permit

26405

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: 511540 Montague Rd
SUBDIVISION Michael Borch LOT # 5

ISSUED TO: DANNY RAY Connell
NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: DWMH

Proposed Wastewater System Type: 25% REDUCTION

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well _____ feet

Permit conditions: _____ Permit valid for: Five years No expiration

Authorized State Agent: James E. Markant Date: 1-7-11 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: DANNY RAY Connell PROPERTY LOCATION: 511540 Montague Rd
SUBDIVISION Michael Borch LOT # 5

Facility Type: DWMH New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** 25% REDUCTION System (Initial) Wastewater Flow: 360 GPD

(See note below, if applicable)

MANIPULATE TO 25% REDUCTION (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Number of trenches 2

Pump Tank Size _____ gallons Exact length of each trench 120 feet Trench Spacing: 9 Feet on Center

Trenches shall be installed on contour at a Maximum Trench Depth of: 28-24-7/8 inches (Maximum soil cover shall not exceed 36" above the trench bottom)

(Trench bottoms shall be level to +/- 1/4" in all directions)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: 6 inches below pipe

FF POWER LINE TO HOME RUNS THROUGH 2 inches above pipe

System Area Contact E.H. 12 inches total

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.

NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Markant Date: 1-7-11
Construction Authorization Expiration Date: 1-7-16

HTE# 10-5-25817

Permit # 26405

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATOR: 501540 Montague RD

ISSUED TO: DANNY RAY CARROLL

SUBDIVISION Michael Borch

LOT # 5

Authorized State Agent: James E. Mackintosh

Date: 1-7-11

