

1-9A-244-8300

Department of Environment, Health and Natural Resources  
 Division of Environmental Health  
 On-Site Wastewater Section

Sheet:  
 Property ID:  
 Lot #:  
 File #:  
 Code:

**SOIL/SITE EVALUATION**  
 for ON-SITE WASTEWATER SYSTEM

Owner:                      Applicant: 25938  
 Address:                      Date Evaluated: -1-27-11  
 Proposed Facility:                      Design Flow (.1949): 360  
 Location of Site:                      Property Recorded:                      Property Size:  
 Water Supply:                       Public                       Individual                       Well                       Spring                       Other  
 Evaluation Method:                       Auger Boring                       Pit                       Cut  
 Type of Wastewater:                       Sewage                       Industrial Process                       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz.	
1	L-T 5% 0-30	0-30	SL	FA GANSP					.06
		40-48	SCL	Fm 1/3 A S.P.					
2	L-T 4% 0-30	0-30	SL	FA GANSP					.04, 5-
		30-48	SCL	Fm 1/3 A S.P.	36" - 38"				
3	L-T 3% 0-32	0-32	SL	FA GANSP					.04
		32-48	SC-CLAY	Fm 1/3 A S.P.	32" - 34"				
4	L-T 3% 0-20	0-20	SL	FA GANSP					.035
		20-36	SC-CLAY	Fm 1/3 A S.P.	32"				
5	L-T 4% 0-32	0-32	SL	FA GANSP					.04
		32-48	SC-CL	Fm 1/3 A S.P.	40"				
6	L-T 4% 0-24	0-24	SL	FA GANSP					.04
		24-42	SC-CL	Fm 1/3 A S.P.	36"				

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: Others Present:
Available Space (.1945)	✓	✓	
System Type(s)	75%	25%	
Site LTAR	.04	.04	

M78 - L-T-4% 0-30 SL - FA GANSP  
 40-48 SCL Fm 1/3 A S.P. .05  
 9, 0-30 SL  
 30-44 SCL  
 42" 7.5% .045