



North Carolina State Laboratory Public Health
Environmental Sciences

Microbiology
Certificate of Analysis

P.O. Box 28047
306 N. Wilmington St.
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7834
Fax: 919-733-8695

Report To:

HARNETT CO ENVIRONMENTAL HEALTH

307 CORNELIUS HARNETT BLVD
LILLINGTON, NC 27546
EIN:566000306EH

Name of System:

NORMAN LEVON CAMERON

PO BOX 336
BROADWAY, NC 27505

StarLiMS Sample ID: **ES041311-0107001**



Collected: 04/12/2011 11:30

Received: 04/13/2011 09:19

Bryan McSwain

Angela Heybroek

ES Microbiology ID: **26291**

GPS Number:

Sample Source: **New Well**

Sampling Point: **Spigot at house**

Well Permit Number:

11-5-25990

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Joy Hayes	04/14/2011
<i>E. coli</i> , Colilert	Absent	Joy Hayes	04/14/2011

Report Date: 04/15/2011

Reported By: **Susan Beasley**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.