

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address:

Date Evaluated:

Proposed Facility:

Design Flow (.1949):

Location of Site:

Property Recorded:

Property Size:

Water Supply:

- Public Individual Well Spring Other
 Auger Boring Pit Cut
 Sewage Industrial Process Mixed

Evaluation Method:

Type of Wastewater:

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1936 Sapro Class	.1944 Restr. Horiz.	
1	L 4%	0-18	SL						
		18-30	SL				30		
		30+	Pm						30 Pm
2	L 4%	0-4	SL						
		4-24	SC-CL-Pm				18-26"		Pm M20'
3	L 3-4%	0-20	SL						
		20-30	SCL				36"		Pm 36+
4	L 3-4%	0-18	SL						
		18-36	SCL				36"		Pm 36"
5	L 3%	0-30	GM						
		30-48	SCL				44"		Pm 44
6	L 4%	0-20							
		20-36					36"		36 Pm

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: Others Present:
Available Space (.1943)	✓	✓	
System Type(s)	602	602	
Site LTAR	04	04	