Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated: 6/30/2011
Proposed Facility: Design Flow (.1949): Property Size:
Location of Site: Property Recorded:
Water Supply: ☐ Public ☐ Individual ☑ Well ☐ Spring ☐ Other
Evaluation Method: ☑ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz.	
	LS 4%	0-12	G/LS	Vfr-NS NP					
		12-42	SBK/SCL	Fr SSSP					PS-4
		0-18	G/LS	Vfr-NS NP					
		18-36	SBK/C	Fr SSP	10YR 7/1 at 36"				PS-3
		0-8	G/LS	Vfr-NS NP					
		8-30	SBK/C	Fr SSP					PS-3

Description	Initial System	Repair System
Available Space (.1945)	/	/
System Type(s)	25%	25%
Site LTAR	.9	.9

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By: [illegible]
Others Present: