

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: David & Alison Deese

Address: 202 Crystal Brook Dr
Angier, NC 27501

Date: 6-13-16

Building Official: [Signature]

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: 11-50027137

ADDRESS : 202 CRYSTAL BROOK DR SUBDIV:
 CONTRACTOR : J M B SERVICES PHONE : (919) 669-7043
 OWNER : DEESE DAVUD & ALISON PHONE : (910) 620-1465
 PARCEL : 07-1602- - -0031- -04-
 APPL NUMBER: 11-50027134 CP MANUFACTURED HOME RA 30 CRITERIA

DIRECTIONS : T/S: 07/14/2011 11:42 AM JBROCK ----
 210 TO ANGIER RIGHT 55 LEFT ON MCGAVER
 ST RIGHT ON JOHNSTON COUNTY RIGHT LIVE
 OAK RD LEFT ON JOHNSTON RD LEFT CRYSTAL
 BREAK DR GO TO END OF RD LOT 4

STRUCTURE: 000 000 28X45 3BDR W/DECK CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 MOBILE HOME YEAR : 1.00
 PROPOSED USE : SFD SEPTIC - EXISTING? : EXIST
 WATER SUPPLY : COUNTY

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E101 01	4/19/16	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002804460
	4/19/16	DA	T/S: 04/19/2016 01:04 PM DETAYLOR ----- Need plans for inspection
E101 02	4/20/16	DT	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002805463
	4/20/16	AP	T/S: 04/20/2016 07:55 AM DJOHNSON ----- T/S: 04/20/2016 02:19 PM DETAYLOR -----
T501 01	5/04/16	DT	R*MOBILE HOME FOUND./ M. WALL VRU #: 002811461
	5/04/16	AP	T/S: 05/04/2016 12:59 PM DETAYLOR -----
A814 01	5/05/16	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002811941
	5/04/16	AP	202 CRYSTAL BROOK DR ANGIER 27501 T/S: 05/04/2016 09:42 AM SBENNETT -----
H824 01	5/11/16	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002816502
	5/11/16	AP	T/S: 05/13/2016 11:58 AM SSTEWARD ----- T/S: 05/13/2016 11:58 AM SSTEWARD -----
A814 02	5/31/16	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002822994
	5/31/16	AP	202 CRYSTAL BROOK DR ANGIER 27501 T/S: 05/31/2016 03:54 PM SBENNETT -----
E307 01	6/03/16	MR	R*PLUMB WATER CONNECTION VRU #: 002825312
	6/03/16	AP	T/S: 06/03/2016 03:02 PM MREARIC -----
Z818 02	6/07/16	AD	PZ*ZONING INSPECTION TIME: 17:00 VRU #: 002825347
	6/07/16	AP	T/S: 06/02/2016 12:44 PM DJOHNSON ----- SCHEDULED INSSPECTION AGAIN. NOT SURE IF IT WAS INSPECTED THE LAST TIME. T/S: 06/06/2016 03:28 PM DJOHNSON ----- T/S: 06/07/2016 07:03 AM ADRIGGER -----
T507 01	6/08/16	KS	R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 002827038
	6/08/16	DA	T/S: 06/07/2016 08:08 AM DJOHNSON ----- T/S: 06/08/2016 03:19 PM KSLATTUM ----- 1. Need receptacle accessible from grade on rear of house and one within 25 feet of outside a/c unit. 2. Need 911 numbers at road on mail box or sign. 3. Need positive drainage away from house.
T507 02	6/13/16	TI	R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 002829463
	6/13/16	AP DV	T/S: 06/10/2016 01:36 PM JFORBES -----