

HTE# 12-5-29604

# Harnett County Department of Public Health

## Improvement Permit

27036

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Marilyn S Matthews PROPERTY LOCATION: 321707 NEIGHBORS RD  
NEW  REPAIR  EXPANSION  SUBDIVISION Marilyn S Matthews LOT # 1  
Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: Dw m H

Proposed Wastewater System Type: AT GRADE TO 2590 (REDOUCED)

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement  Yes  No

Pump Required:  Yes  No  May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well Distance from well \_\_\_\_\_ feet Permit valid for:  Five years

Permit conditions: \_\_\_\_\_  No expiration

Contractor to meet ONSETT Prior to INSTALL

Authorized State Agent: James E Markant Date: 9-6-12 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Marilyn S Matthews PROPERTY LOCATION: 321707 NEIGHBORS RD  
SUBDIVISION Marilyn Matthews LOT # 1

Facility Type: Dw m H  New  Expansion  Repair

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* AT GRADE TO 2590 (REDOUCED) SYSTEM (Initial) Wastewater Flow: 360 GPD

(See note below, if applicable ) Fell system (Repair)

Installation Requirements/Conditions Number of trenches 3

Septic Tank Size 1000 gallons Exact length of each trench 110 feet Trench Spacing: 7 Feet on Center

Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6 inches

Maximum Trench Depth of: 12" max inches (Maximum soil cover shall not exceed 36" above the trench bottom)

(Trench bottoms shall be level to +/- 1/4" in all directions)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM Aggregate Depth: 6 inches below pipe

2 inches above pipe

Conditions: Contractor to meet ONSETT 12 inches total

Prior to INSTALL

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.  
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E Markant Date: 9-6-12  
Construction Authorization Expiration Date: 9-6-17

HTE# 12-5-29604

Permit # 27036

# Harnett County Department of Public Health Site Sketch

PROPERTY LOCATION: SR1707 NEIGHBOURS RD

ISSUED TO: Marilyn S Matthews SUBDIVISION Marilyn Matthews LOT # 1

Authorized State Agent: [Signature] Date: 9-6-12

