

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes, For the following:

Use Classification: Residential

Name: Louis Altomer

Address: 39 Crystal Brook Dr.

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: 13-50030611

Date: 4-16-13

Building Official: Ken Slatt

ADDRESS : 39 CRYSTAL BROOK DR SUBDIV:
 CONTRACTOR : TITAN DESIGNS MANAGEMENT PHONE : (910) 258-1348
 OWNER : ALTOMER LOUIS J & KATHRYN PHONE :
 PARCEL : 07-1602- - -0031- -01-
 APPL NUMBER: 13-50030611 CP MANUFACTURED HOME RA 30 CRITERIA
 DIRECTIONS : T/S: 02/11/2013 12:56 PM VBROWN ----
 #1 CRYSTAL BROOK DRIVE
 27E, TO DIXON ROAD TO RIGHT COME TO
 GROSS RD GO THRU CROSS RD, ABOUT 3 MI
 ON RIGHT.
 T/S: 03/27/2013 02:48 PM VBROWN ----
 PREMIS NUMBER 66718698

STRUCTURE: 000 000 35X50 3BDR DWMH

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 MOBILE HOME YEAR : 1000.00
 PROPOSED USE : DWMH SEPTIC - EXISTING? : NEW TANK
 WATER SUPPLY : COUNTY

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
H824 01	3/04/13 3/04/13	JM DA	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002346617 PER JAMES MANHART NEEDS WATER AND POWER CHECKED PRIOR TO OPERATIONS PERMIT BEING ISSUED FOR SEPTIC TANK. CALL HIM WHEN READY TO INSPECT, 910-893-7547. T/S: 03/04/2013 08:40 AM SSTEWARD T/S: 03/04/2013 08:41 AM SSTEWARD
T501 01	3/05/13 3/05/13	DT DA	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002346658 T/S: 03/05/2013 10:49 AM DETAYLOR Need plumbing test on Missing longitudinal strap on front left of home Marriage wall okay to close in but do not underpin until after the re-inspection
T501 02	3/13/13 3/13/13	DT AP	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002350841 T/S: 03/12/2013 09:39 AM VBROWN T/S: 03/13/2013 02:03 PM DETAYLOR
H824 02	3/15/13 3/15/13	JM AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002353738 T/S: 03/19/2013 11:16 AM SSTEWARD T/S: 03/19/2013 11:16 AM SSTEWARD
A814 01	3/28/13 4/04/13	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002358158 T/S: 03/27/2013 01:28 PM VBROWN 39 crystal brook dr lot 1 angier 27501
Z818 01	3/28/13 3/28/13	RB AP	PZ*ZONING INSPECTION TIME: 17:00 VRU #: 002358141 T/S: 03/27/2013 01:28 PM VBROWN
T507 01	4/05/13 4/05/13	DT DA	R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 002361574 T/S: 04/04/2013 09:19 AM DJOHNSON T/S: 04/05/2013 11:09 AM DETAYLOR House numbers (39) must be fastened to front of house. Stairs must be uniform (within 3/8 inch of one another) If a step is needed to make up the difference, it must be the bottom step to grade, not the top
T507 02	4/08/13 4/08/13	KS DA	R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 002362762 T/S: 04/08/2013 11:11 AM KSLATTUM

ADDRESS : 39 CRYSTAL BROOK DR SUBDIV:
CONTRACTOR : TITAN DESIGNS MANAGEMENT PHONE : (910) 258-1348
OWNER . . : ALTOMER LOUIS J & KATHRYN PHONE :
PARCEL . . : 07-1602- - -0031- -01-
APPL NUMBER: 13-50030611 CP MANUFACTURED HOME RA 30 CRITERIA

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T507 03	4/16/13	TI	Top step of home on front not uniform with others. R*MANUFACTURED HOME FINAL VRU #: 002366503

----- COMMENTS AND NOTES -----

ADDRESS : 39 CRYSTAL BROOK DR SUBDIV:
 CONTRACTOR : TITAN DESIGNS MANAGEMENT PHONE : (910) 258-1348
 OWNER : ALTOMER LOUIS J & KATHRYN PHONE :
 PARCEL : 07-1602- - -0031- -01-
 APPL NUMBER: 13-50030611 CP MANUFACTURED HOME RA 30 CRITERIA
 DIRECTIONS : T/S: 02/11/2013 12:56 PM VBROWN ----
 #1 CRYSTAL BROOK DRIVE
 27E, TO DIXON ROAD TO RIGHT COME TO
 GROSS RD GO THRU CROSS RD, ABOUT 3 MI
 ON RIGHT.

STRUCTURE: 000 000 35X50 3BDR DWMH
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 MOBILE HOME YEAR : 1000.00
 PROPOSED USE : DWMH SEPTIC - EXISTING? : NEW TANK
 WATER SUPPLY : COUNTY

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
H824 01	3/04/13 3/04/13	JM DA	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002346617 PER JAMES MANHART NEEDS WATER AND POWER CHECKED PRIOR TO OPERATIONS PERMIT BEING ISSUED FOR SEPTIC TANK. CALL HIM WHEN READY TO INSPECT, 910-893-7547. T/S: 03/04/2013 08:40 AM SSTEWARD ----- T/S: 03/04/2013 08:41 AM SSTEWARD -----
T501 01	3/05/13 3/05/13	DT DA	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002346658 T/S: 03/05/2013 10:49 AM DETAYLOR ----- Need plumbing test on Missing longitudinal strap on front left of home Marriage wall okay to close in but do not underpin until after the re-inspection
T501 02	3/13/13 3/13/13	DT AP	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002350841 T/S: 03/12/2013 09:39 AM VBROWN ----- T/S: 03/13/2013 02:03 PM DETAYLOR -----
H824 02	3/15/13 3/15/13	JM AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002353738 T/S: 03/19/2013 11:16 AM SSTEWARD ----- T/S: 03/19/2013 11:16 AM SSTEWARD -----
A814 01	3/28/13	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002358158 T/S: 03/27/2013 01:28 PM VBROWN -----
Z818 01	<u>3/28/13</u> <u>3/28/13</u>	TI <u>RB/AP</u>	PZ*ZONING INSPECTION TIME: 17:00 VRU #: 002358141 T/S: 03/27/2013 01:28 PM VBROWN -----

COMMENTS AND NOTES

CONF.# 129188