

ADDRESS : 365 NORRINGTON RD
CONTRACTOR :
OWNER : MANGUM DONALD & OLIVIA
PARCEL : 13-0528- - -0022- -08-
APPL NUMBER: 13-50032633 CP MANUFACTURED HOME RA 30 CRITERIA
DIRECTIONS : T/S: 12/16/2013 03:31 PM JBROCK ----
NEXT TO 325 NORRINGTON RD

SUBDIV:
PHONE :
PHONE :

STRUCTURE: 000 000 28X76 3BDR DWMH

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : DWMH
WATER SUPPLY : COUNTY

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|-------------|---|
| H824 01 | 10/29/14 | OT | ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002594356 |
| | 10/29/14 | AP | T/S: 10/30/2014 10:32 AM SSTEWARD ----- T/S: 10/30/2014 10:33 AM SSTEWARD ----- |
| T501 01 | 10/30/14 | MR | R*MOBILE HOME FOUND./ M. WALL VRU #: 002593689 |
| | 10/30/14 | DA | T/S: 10/30/2014 09:00 AM MREARIC ----- drain test is not ready or installed. |
| T501 02 | 11/04/14 | MR | R*MOBILE HOME FOUND./ M. WALL VRU #: 002595049 |
| | 11/04/14 | DA | T/S: 11/04/2014 09:34 AM MREARIC ----- not ready still..... |
| T501 03 | 11/05/14 | MR | R*MOBILE HOME FOUND./ M. WALL VRU #: 002595593 |
| | 11/05/14 | AP | T/S: 11/05/2014 01:21 PM MREARIC ----- |
| A814 01 | 11/21/14 | TW | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002601474 |
| | 11/21/14 | AP | 365 Norrington Rd lillington 27546 T/S: 11/21/2014 10:40 AM TWARD ----- T/S: 11/21/2014 10:41 AM TWARD ----- |
| Z818 01 | 11/24/14 | RB | PZ*ZONING INSPECTION TIME: 17:00 VRU #: 002601466 |
| | 11/24/14 | AP | T/S: 11/20/2014 12:53 PM VBROWN ----- |
| T507 01 | 11/25/14 | MR | R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 002602415 |
| | 11/25/14 | DA | T/S: 11/25/2014 12:16 PM MREARIC ----- install door on crawlspace / steps must be built to code / back door requires a landing 3x3 / pipe to septic tank must be 2" / grade around foundation to shed water away / you need heating installed / atach ground wire to wall / install smooth wall dryer vent / install all lights |
| T507 02 | 12/12/14 | TI | R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 002608057 |
| | | | T/S: 12/11/2014 08:30 AM DJOHNSON ----- |

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Manufactured Home

PERMIT NUMBERS

Owner: Donald + Olivia Mangum

Building Permit No.: _____

911 Address: 365 Norrington Rd

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

State: NC Zip Code: _____

Mech. Permit No.: _____

Date: 12/12/14

MFG. Home: _____

S Guy

Building Official