Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated: 11-2
Proposed Facility: Design Flow (.1949): 360 Property Size:
Location of Site: Property Recorded:
Water Supply: ☑ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☑ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1, 2	C-3%	0-18	SL	FR GR NONP					
		18-42	SCL	FR SBK SSS	44" 7.5YR 3/4				.4
3, 4	C-3%	0-24	SL	FR GR NONP					
		24-48	SCL	FR SBK SS	46" 7.5YR 3/4				.4

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	182	2 3 4
Site LTAR	.4	.4

Other Factors (.1946):
Site Classification (.1948): P5
Evaluated By:
Others Present: 2