

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: _____ Applicant: *VDF*
 Address: _____ Date Evaluated: _____
 Proposed Facility: *2FD* Design Flow (.1949): _____ Property Size: _____
 Location of Site: _____ Property Recorded: *[Signature]*
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,2	<i>5% L-T</i>	0-18	<i>2L-2.2L</i>	<i>CL GL N&NP</i>					
		18-36	<i>5C-5CL</i>	<i>fm 1/2 CL S.P.</i>	<i>36" fm</i>	<i>36"</i>		<i>fm</i>	<i>.4</i>
3,4	<i>5-6% L-</i>	0-15	<i>5L</i>	<i>CL GL N&NP</i>					
		15-36	<i>5CL</i>	<i>5L fm 1/2 CL S.S.P.</i>					
		36"	<i>7L</i>	<i>fm 1/2 CL S.P.</i>	<i>34-36" fm</i>	<i>34-36"</i>		<i>P2</i>	<i>.4</i>
5	<i>6% L</i>	0-12	<i>5L</i>	<i>CL GL N&NP</i>					
		12-34	<i>5CL</i>	<i>CL fm 1/2 CL S.P.</i>	<i>26-32" P-</i>				<i>.3</i>
6	<i>6% L</i>	0-10	<i>5L</i>	<i>CL GL N&NP</i>					
		10-36	<i>5CL</i>	<i>fm 1/2 CL S.P.</i>	<i>34-36" P2</i>	<i>36</i>		<i>fm</i>	<i>.3</i>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>PS</i> Evaluated By: <i>JH</i> Others Present:
Available Space (.1945)	<i>1</i>	<i>1</i>	
System Type(s)	<i>2822</i>	<i>24</i>	
Site LTAR	<i>.3</i>	<i>.4</i>	