

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Manufactured 2x

Permit Numbers

Name: David W & Linda Chandler

Building: _____

Electrical: _____

Address: 390 Creekside Dr.

Insulation: _____

Plumbing: _____

Angier NC 27501

Mechanical: _____

MFG Home: 16-50038040

Date: 10/19/2016

Building Official: Brad Sutton

ADDRESS : 390 CREEKSIDE DR SUBDIV: CREEK SIDE FARMS
 CONTRACTOR : KARL CARTER PHONE : (919) 422-0428
 OWNER : CHANDLER DAVID W & LINDA D PHONE : (919) 639-9602
 PARCEL : 04-0664- - -0005- - -
 APPL NUMBER: 16-50038040 CP MANUFACTURED HOME RA 30 CRITERIA
 DIRECTIONS : T/S: 10/07/2016 09:17 AM LBENNETT --
 PREMISE#04142434

STRUCTURE: 000 000

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : EXIST SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/10/16 10/11/16	BS AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002882199 T/S: 10/06/2016 12:49 PM DJOHNSON T/S: October 11, 2016 01:00 PM BSUTTON Front and rear deck footings approved
R131 01	10/19/16 <i>10/19/16</i>	TI <i>APBS</i>	ONE TRADE FINAL TIME: 17:00 VRU #: 002886125 T/S: 10/17/2016 02:44 PM LBENNETT

PERMIT: CPDW 00 CP MOBILE HOME DOUBLEWIDE

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
T501 01	8/24/16 8/24/16	BS DA	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002860294 T/S: 08/19/2016 04:19 PM LBENNETT T/S: 08/22/2016 11:06 AM LBENNETT T/S: August 24, 2016 08:55 AM BSUTTON More than 1/4 of the home is above 36 inches. Need engineering on tie down system.
T501 02	9/15/16 9/15/16	BS AP	R*MOBILE HOME FOUND./ M. WALL TIME: 17:00 VRU #: 002872620 T/S: 09/15/2016 03:16 PM LBENNETT PROVIDED AN ENGINEERS LETTER T/S: 09/15/2016 03:16 PM LBENNETT
A814 01	10/07/16 10/07/16	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002882181 390 Creekside Dr Angier 27501 T/S: 10/07/2016 12:29 PM TWARD T/S: 10/07/2016 12:30 PM TWARD
Z818 01	10/07/16 10/07/16	AD AP	PZ*ZONING INSPECTION TIME: 17:00 VRU #: 002882165 T/S: 10/06/2016 12:49 PM DJOHNSON T/S: 10/07/2016 02:18 PM ADRIGGER
T507 01	10/19/16	TI	R*MANUFACTURED HOME FINAL TIME: 17:00 VRU #: 002886117 T/S: 10/17/2016 02:43 PM LBENNETT T/S: 10/17/2016 02:44 PM LBENNETT

COMMENTS AND NOTES