HTE# 16-5-4025 7 Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: Stevent Road (SR 1810) Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 3BR Manufactered Home Proposed Wastewater System Type: 25%0 Reduction System Projected Daily Flow: 36 GPD Pump Required:

Yes

No

May be required based on final location and elevations of facilities

Type of Water Supply:

Community

Public

Well

Distance from well

feet

Permit valid for: Five years Permit conditions: ■ No expiration Authorized State Agent:

Date:

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit... **Construction Authorization** (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance ISSUED TO: Dennis + Rachel Starting PROPERTY LOCATION: Stewart Road (SR 1810)

SUBDIVISION LOT # //

Facility Type: 3BR Manufactured Home Wew Expansion Repair Basement? Yes No Basement Fixtures? Yes No Type of Wastewater System** 25% Reduction System (Initial) Wastewater Flow: 360 GPD (See note below, if applicable) 25% Reduction 575/2m (Repair) Number of trenches _____3 Installation Requirements/Conditions Exact length of each trench 70 feet Trench Spacing: 9 Feet on Center Septic Tank Size 900+ gallons Pump Tank Size gallons Soil Cover: 6+ inches Trenches shall be installed on contour at a Maximum Trench Depth of: ______ inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. GPM Conditions: WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Date: 01/03/17

Construction Authorization Expiration Date: 01/03/22

Harnett County Department of Public Health Site Sketch

