

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: Design Flow (.1949): Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L9 02	0-20	G LS	VFH NS/VP					
		20-44	SBK SCL	F2 SS/VP					P3 -43
2		0-24	G LS	VFH NS/VP					
		24-36	SBK SCL	F2 SS/VP					
		36-44	SBK SCL	F2 SS/SP					P5 4
		0-20	G LS	VFH NS/VP					
		20-39	SBK C	F2 SS/SP	WAT @ 38"				P5 2

Description	Initial System <input checked="" type="checkbox"/>	Repair System <input checked="" type="checkbox"/>	Other Factors (.1946): <input checked="" type="checkbox"/> Site Classification (.1948): Evaluated By: <input checked="" type="checkbox"/> Others Present: <input checked="" type="checkbox"/>
Available Space (.1945)			
System Type(s)	250	100	
Site LTAR	1	1	

3x75 @ 18-20

