

**Improvement Permit**

A building permit cannot be issued with only an Improvement Permit

SR 1703

ISSUED TO: Adams Homes, LLC  
NEW  REPAIR  EXPANSION   
Type of Structure: 4BR 60'x67' SFD  
Proposed Wastewater System Type: 25% reduction sys.  
Projected Daily Flow: 480 GPD  
Number of bedrooms: 4 Number of Occupants: 8 max  
Basement  Yes  No  
Pump Required:  Yes  No  May be required based on final location and elevations of facilities  
Type of Water Supply:  Community  Public  Well Distance from well NA feet  
Permit conditions: \_\_\_\_\_

PROPERTY LOCATION: 125 Trolley Ln. (Red Hill Ch. Rd.)  
SUBDIVISION Cane Mill Ests LOT # 22  
Site Improvements required prior to Construction Authorization Issuance: \_\_\_\_\_

Permit valid for:  Five years  
 No expiration

Authorized State Agent: [Signature] Date: 08/23/2018 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

**Construction Authorization**

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Adams Homes, LLC

PROPERTY LOCATION: 125 Trolley Ln. (Red Hill Ch. Rd.)  
SUBDIVISION Cane Mill Ests LOT # 22

Facility Type: 4BR 60'x67' SFD  New  Expansion  Repair

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* 25% reduction system (Initial) Wastewater Flow: 480 GPD

(See note below, if applicable ) 25% reduction sys. (Repair)

**Installation Requirements/Conditions**

Septic Tank Size 1250 gallons  
Pump Tank Size \_\_\_\_\_ gallons

Number of trenches 3  
Exact length of each trench 100 feet  
Trenches shall be installed on contour at a  
Maximum Trench Depth of: 20 inches  
(Trench bottoms shall be level to +/-1/4"  
in all directions)

Trench Spacing: 9 Feet on Center  
Soil Cover: 8 inches  
(Maximum soil cover shall not exceed  
36" above the trench bottom)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM

Aggregate Depth: NA inches below pipe  
NA inches above pipe  
NA inches total

Conditions: \_\_\_\_\_

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.  
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.  
Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 08/23/2018 02/28/2019  
ANDREW CURRY Construction Authorization Expiration Date: 08/23/2023 02/28/2024

HTE# SFD1807-00312

Permit # 30165

# Harnett County Department of Public Health Site Sketch

SN 1763

PROPERTY LOCATOR: 125 Trolly Ln. (Red Hill Ch. rd)

ISSUED TO: Adams Homes, LLC

SUBDIVISION Cape Mill Pkts

LOT # 22

Authorized State Agent: [Signature]

Date: 02/25/2019

