

HTE# 1808-0006

Harnett County Department of Public Health

30169

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

521210

ISSUED TO: Ben Stout Construction

PROPERTY LOCATION: 166 Old Field Loop (Hoover Road)

NEW REPAIR EXPANSION

SUBDIVISION Persimmon Hill LOT # 16

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: 402 46'x37' SFD

Proposed Wastewater System Type: 25% reduction Sys.

Projected Daily Flow: 480 GPD

Number of bedrooms: 4 Number of Occupants: 8 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well NA feet

Permit valid for: Five years No expiration

Permit conditions:

Authorized State Agent: [Signature]

Date: 08/29/2018

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Ben Stout Construction

PROPERTY LOCATION: 166 Old Field Loop (Hoover Rd.)

521210

SUBDIVISION Persimmon Hill LOT # 16

Facility Type: 402 46'x37' SFD New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** 25% Reduction System (Initial) Wastewater Flow: 480 GPD

(See note below, if applicable)

25% Reduction System (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons

Pump Tank Size _____ gallons

Number of trenches 1

Exact length of each trench 240 feet

Trenches shall be installed on contour at a

Maximum Trench Depth of: 18-24 inches

(Trench bottoms shall be level to +1-1/4"

in all directions)

Trench Spacing: 9 Feet on Center

Soil Cover: 6-12 inches

(Maximum soil cover shall not exceed

36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: NA inches below pipe

NA inches above pipe

NA inches total

Conditions:

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____

Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This

Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature]

Date: 08/29/2018

ANDREW WARRIN

Construction Authorization Expiration Date: 08/29/2023


HTE# 1808-0006


Permit # 30169

Harnett County Department of Public Health Site Sketch

SR 1210

ISSUED TO: Ben Stout Construction PROPERTY LOCATOR: 166 Old Field Loop (Hoover Road)
SUBDIVISION: Persimmon Hill LOT # 16

Authorized State Agent:  Date: 08/29/2018
ANDREW CURRAN



SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: *Regency Homes* Applicant: *Ben Stout Const.* Date Evaluated: *08/24/2018*
 Address: *166 Old Field Way* Design Flow (.1949): *480 GPD* Property Size:
 Location of Site: *482 S/O* Property Recorded: *1/13*
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

PERSIMMON HILL
S/O
Lot 16

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 2-5%	0-30	<i>C2 L/SL</i>	<i>VR NSNP</i>					<i>PS</i>
		30-48	<i>OL SL</i>	<i>CL SSSR</i>		<i>48</i>			<i>0.5</i>
2,3	L 2-5%	0-24	<i>CL L/SL</i>	<i>VR NSNP</i>					<i>PS</i>
		24-48	<i>OL SL</i>	<i>CL SSSR</i>		<i>48</i>			<i>0.5</i>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948):
Available Space (.1945)	<i>25% red</i>	<i>25% red</i>	<i>Provisionally Suitable</i>
System Type(s)	<i>0.5</i>	<i>0.5</i>	Evaluated By: <i>Andrew Curran</i>
Site LTAR	<i>0.5</i>	<i>0.5</i>	Others Present: