

H & H Homes  
2919 Breezewood Avenue  
Suite 400  
Fayetteville, NC 28303

*295 Birch Ave.*

10/15/2018

Attention : John Rice  
Matt Betts

*SFD 1808-0007*

**RE:** Daily Field Report for 10/05/2018  
Lot 102 Cooper's Creek CPC (CMT) Spring Lake, NC  
Building & Earth Project No : RD180547

Ladies and Gentlemen:

On this date, representative(s) of Building & Earth were present to perform construction material testing services at this project site. Our testing and observations for this date include the following:

**FO-1 :** Field Observations made on this date.

- Foundation Inspection-Monolithic Passed
- Project Management Review Passed

**ST-1 :** In place field density testing was performed for Finished Subgrade Soils -Building. The field density testing was performed in general accordance with ASTM D1556, using the results of field one-point as compared to the laboratory proctors. One(1) in-place field density test was performed on this date. The testing results indicate that in-place compaction and moisture content at the location and depth tested meet or exceed the specified requirements outlined in the project plans and specifications. For additional details of our testing, please refer to the attached Field Density Test Report.

**Closing**

The testing and observations identified above have been reviewed by our project manager. If you have questions regarding this information, please do not hesitate to contact us.

Respectfully Submitted,  
Building & Earth Sciences, LLP

**Enclosures :** FO-1, ST-1



*Rachael Heath*  
Reviewed By