


**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 3 BDRM Design Flow (.1949): 360 gpd Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941		.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
			.1941 Structure/ Texture	.1941 Consistence Mineralogy					
1	LS 0-2	0-12	G SL	VFI NS/NP					
		12-36	SBK CL	FI SS/NP					PS .45
		36	G S	VFI NS/NP					
2		0-12	G SL	VFI NS/NP					
		12-32	SBK CL	FI SS/NP					PS .45
		32-48	G S	VFI NS/NP					
3		0-12	G SL	VFI NS/NP					
		12-38	SBK CL	FI SS/NP					PS .45
		38-48	G S	VFI NS/NP					

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: BT Others Present: -
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	PV.MP	25% RBD	
Site LTAR	.45	.45	



Notes

- This plat is for location purposes only. Builder should verify foundation information with plans before construction begins.
- There is no USCE or NCGS monument within 2000' of this site.
- The subject property is not within a special flood hazard area as determined by the Department of Housing and Urban Development.
- The easement information shown hereon was obtained from the recorded plat. No updated title search was performed by the surveyor.
- All distances are measured in feet.
- This map reflects the information contained on the Record Plat and does not represent compliance with the Restrictive Covenants.


LEGEND

- - EXISTING IRON PIPE
- - CURVE PT / PC
- - SURVEYED LINE
- - - - EASEMENT LINE
- - - - ADJOINER
- - - - SURVEYED BY OTHERS

SCALED IN FEET

NOTE: THERE IS A RESERVED 5' DRAINAGE AND UTILITY EASEMENT ALONG EACH SIDE AND REAR OF ALL LOT LINES IN THE SUBDIVISION

PRELIMINARY PLAT - NOT FOR CONVEYANCES OR SALES



SWEETWATER
LOT SETBACKS PER COVENANTS
DB8353/PG13-22

FRONT	35' MIN
SIDE (Internal)	10' MIN
SIDE STREET (Corner)	20' MIN
REAR	25' MIN
REAR (Detached Bldg)	15' MIN

FARROW COURT
40' PUBLIC/UTILITY R/W