

**R o b e r t      C h a r l e s      E v a n s**

**A      r      c      h      i      t      e      c      t**

5   4   5            P   e   a   r   l            S   t   r   e   e   t  
F a y e t t e v i l l e ,    N o r t h    C a r o l i n a    2 8 3 0 3

**T   R   A   N   S   M   I   T   T   A   L**


11 January 2019

re: Mohler Homes, Inc.  
Lot 108, Expedition Drive  
Lexington Plantation  
Harnett County, North Carolina

To Whom it May Concern,

The wood piers shall be comprised of double 2x8 pt at the sides and top with a single bottom plate anchored to the CMU pier with (2) 1/2"x8" anchor bolts. The wood pier is to be sheathed with 1/2" OSB each side for lateral stability.

If you have any questions concerning this transmittal, please call me at 910.624.9259.



Robert Charles Evans  
NC Registered Architect 6530