



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918

http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to: JAMES MANHART**

**Name of System:**

**HARNETT CO ENVIRONMENTAL HEALTH**

**Robert Appel**

**307 CORNELIUS HARNETT BLVD**

**944 McLamb Rd**

**Lillington, NC 27546**

**Coats, NC 27521**

**EIN: 566000306EH**

**Delivery: NC Courier**

**Harnett County**

StarLiMS ID: **ES190221-0072**

Date Collected: 02/20/2019

Time Collected: 12:00

By: James E Manhart

Date Received: 02/21/2019

Time Received: 08:37

By: Angela Heybroek

Sample Source: New Well

Sampling Point: Well head

Sample Type: Raw

GPS No.

Treatment:

Well Permit No.

Comment: No permit # given with sample.

**Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			02/21/2019
E. coli	Absent			02/21/2019

**Report Date:** 02/25/2019

**Reported By:** Susan Beasley

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.

North Carolina Division of Public Health  
Occupational and Environmental Epidemiology Branch, Epidemiology Section  
BIOLOGICAL ANALYSIS REPORT

Private well water information and recommendations

County: HARNETT Name: Robert Appel Sample ID Number: ES 190221-0072  
Location: 944 McComb Rd Reviewer: JUSTIN BEASLEY

Initial Sample  Confirmation Sample

BIOLOGICAL ANALYSIS RESULTS AND RECOMMENDATIONS FOR USES OF YOUR PRIVATE WELL WATER (These recommendations are based on biological analysis only.)

No coliform bacteria were found in your well water. Your water can be used for all purposes including drinking, cooking, washing dishes, bathing and showering.

Total coliform bacteria were detected in the sample which indicates that harmful bacteria from human or animal waste could enter the well. Do not use the water for drinking or cooking unless it has been boiled for 3 minutes. You may use your water for all other purposes including washing dishes, bathing or showering.

Your well water needs to be re-tested to verify that the result is accurate.

Fecal coliform bacteria were detected in the sample. Do not use the water for drinking, cooking, washing dishes, bathing or showering.

If the re-test shows contamination by bacteria contact your local health department for assistance. There may be a problem with the construction of the well, the groundwater source, or operation of the well. The well needs to be inspected by the local health department or a local well contractor to determine the problem with the well and to give guidance on how to correct the problem.

Your well water was tested for biological contaminants (total coliform and fecal coliform bacteria). The results were evaluated using the federal drinking water standards.

Drinking water may contain substances that can occur naturally in water or can be introduced into water from man-made sources. Total coliform bacteria are found in soil and fecal coliform bacteria are found in animal and human waste. Total coliform or fecal coliform bacteria in well water indicate that the well may have structural problems or that the well was not properly disinfected.

If you have been drinking the well water and are pregnant, nursing, have a child in the household under 5 years of age, or immunocompromised (such as an individual with AIDS, cancer, hepatitis, dialysis or surgical procedures) inform your physician of these results at your next visit.

If the contamination continues, you should investigate the possibility of drilling a new well or installing a point-of-entry disinfection unit which can use chlorine, ultraviolet light, or ozone.

For further information please contact your county health department or the Occupational and Environmental Epidemiology Branch at 919-707-5900.



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Inorganic Chemistry**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
 http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**Certificate of Analysis**

**FINAL REPORT**

**Report to: JAMES MANHART**

**Name of System:**

**HARNETT CO ENVIRONMENTAL HEALTH**  
**307 CORNELIUS HARNETT BLVD**  
**LILLINGTON, NC 27546**

**Robert Appel**  
**944 McLamb Rd**  
**Coats, NC 27521**

**EIN: 566000306EH**

**Delivery: NC Courier**

StarLiMS ID: **ES190221-0008**

Date Collected: 02/20/2019

Time Collected: 12:00

By: James E Manhart III

Date Received: 02/21/2019

Time Received: 07:39

Sample Type: Raw

Sampling Point: Well head

Well Permit No.

Sample Source: New Well

Receipt Temp.: 2.5 °C

GPS Number:

Comment: No permit # given with sample.

**Profile: New Well I**

Analyte	Test Result	Allowable Limit	Unit	Qualifier(s)
Arsenic	<0.005	0.010	mg/L	
Barium	0.38	2.0	mg/L	
Cadmium	<0.001	0.005	mg/L	
Calcium	19		mg/L	
Chloride	6.17	250	mg/L	
Chromium	<0.01	0.10	mg/L	
Copper	<0.05	1.3	mg/L	
Fluoride	<0.2	4	mg/L	
Iron	0.76	0.30	mg/L	
Lead	<0.005	0.015	mg/L	
Magnesium	7		mg/L	
Manganese	0.45	0.05	mg/L	
Mercury	<0.0005	0.002	mg/L	
Nitrate	<1	10.0	mg/L	
Nitrite	<0.1	1.00	mg/L	
pH	7.7		N/A	
Selenium	<0.005	0.05	mg/L	
Silver	<0.05	0.10	mg/L	
Sodium	7.2		mg/L	
Sulfate	<5	250	mg/L	
Total Alkalinity	88		mg/L	
Total Hardness	75		mg/L	
Zinc	0.06	5.00	mg/L	



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Inorganic Chemistry**

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

**Certificate of Analysis**

**FINAL REPORT**

**Report Date:** 03/05/2019

**Reported By:** *Cindy Price*  
Cindy Price



# Private Well Information and Use Recommendations

## For Inorganic Chemical Contaminants

County: HAYWELL

Name: Robert Appel

Sample ID #: FS 190221-0008

Reviewer: Susan Benschey Jones Monahan

### TEST RESULTS AND USE RECOMMENDATIONS

1.  Your well water meets federal drinking water standards *for inorganic chemicals*. Your water can be used for drinking, cooking, washing, cleaning, bathing, and showering based on the ***inorganic chemical results only***. You may have other water sampling results that are not taken into account in this report.
2.  The following substance(s) exceeded federal drinking water standards or the North Carolina 2L calculated health levels. The North Carolina Division of Public Health recommends that your well water not be used for drinking and cooking, unless you install a water treatment system to remove the circled substance(s). However, it may be used for washing, cleaning, bathing and showering based on the ***inorganic chemical results only***.

Arsenic	Barium	Cadmium	Chromium	Copper	Fluoride	Lead	Iron	
Manganese	Mercury	Nitrate/Nitrite	Selenium	Silver	Magnesium	Zinc	pH	

3.  a. Sodium levels exceed the U.S. Environmental Protection Agency's (USEPA) Health Advisory level for sodium of 20 mg/l. The North Carolina Division of Public Health recommends that only individuals on no or low sodium restricted diets not use this water for drinking or cooking. It may be used for washing, cleaning, bathing, and showering based on the ***inorganic chemical results only***.
- b. Levels over 30 mg/l may pose aesthetic problems such as bad taste, odor, staining of porcelain, etc.
4.  Re-sampling is recommended in \_\_\_\_\_ months.
5.  Re-sample for lead and /or copper. Take a first draw, 5 minute, and 15 minute sample inside the house (preferably the kitchen) and if possible a first draw, 5 minute and a 15 minute sample at the well head to determine the source of the lead and/or copper.
6.  The following substance(s) exceeded federal drinking water standards. Your water can be used for drinking, cooking, washing, cleaning, bathing, and showering based on the ***inorganic chemical results only***, but aesthetic problems such as bad taste, odor, staining of porcelain, etc. may occur. You may want to install a household water treatment system to address aesthetic problems.

Barium	Cadmium	Chromium	Fluoride	Iron	Magnesium
Manganese	Selenium	Silver	pH	Zinc	

*For more information regarding your well water results, please call the North Carolina Division of Public Health at 919-707-5900.*