Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section Sheet: Property ID:

Lot #: File #: Code: SAD1810-0002

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

0 1 1 5 1 1 1 0 1		South Clas
Owner: - Applicant: Signature Home Olds		.10
Address: 99 Boyures Rd Proposed Facility: 480 BT Location of Site: 480 BT Property Recorded: 1949: 480 BT		104 40
Proposed Facility: 487 519 Location of Sire: 487 519 Proposety Percentage: 480 519	Property Size:	Lo-C
Location of Site.		
Water Supply:	☐ Spring	Other
Evaluation Method: Auger Boring Pit Cut		
Type of Wastewater: Sewage Industrial Process	☐ Mixed	

	T		1		1				Т
PROFILE#	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941 .1941 Structure/ Consistence		OTHER PROFILE FACTORS .1942 Soil .1943 .1956 .1944 Wetness/ Soil Sapro Restr				Profile Class
			Texture	Mineralogy	Color	Depth (IN.)	Class	Horiz	& LTAR
1,3	L 3-4%	0-14	CA LS	TN 4558					PS
		14-48	BN SLC	TN 5558		48			P5
	!								
3	L 3-4%	0-13	GR LS	MZ NOND					P3
		12-44	on su	ra 55%	7,54191044"	44			P3
				,	500 =				
						y.			

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948):	Provisionally Svitable
Available Space (.1945)			Evaluated By:	Λ ' ' ' '
System Type(s)	25% Avc	25% ric	Others Present:	HADRED CURTA MEHS
Site LTAR	6.4	0.4	1)	

COMMENTS: ____


LANDSCAPE POSITIONS	<u>GROUP</u>	<u>TEXTURES</u>	. <u>1955 LTAR</u>	CONSISTENCE MOIST	WET
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE	I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE	II	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC
CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	III	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3		SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC

ΙV SIC-SILTY CLAY 0.4 - 0.1 C-CLAY SC-SANDY CLAY

STRUCTURE SG-SINGLE GRAIN M- MASSIVE CR-CRUMB **GR-GRANULAR** SBK-SUBANGULAR BLOCKY ABK-ANGULAR BLOCKY PL-PLATY

MINERALOGY SLIGHTLY EXPANSIVE

EXPANSIVE



BAYVITEW ROAS