



SOUTHEASTERN SOIL & ENVIRONMENTAL ASSOC., INC.

PROPOSED SUBSURFACE WASTE DISPOSAL SYSTEM DETAIL SHEET

SUBDIVISION: OAKMONT

LOT 200

INITIAL SYSTEM: APPROVED 25% REDUCTION <sup>pump to</sup>

REPAIR APPROVED 25% REDUCTION <sup>pump to</sup>

DISTRIBUTION: SERIAL

DISTRIBUTION SERIAL

BENCHMARK: 100.0

LOCATION RC 200/201

NO. BEDROOMS: 4

LTAR 0.5 GPO/FT<sup>2</sup>

LINE                      FLAG COLOR                      ELEVATION                      LENGTH

1	P	100.58	50'
2	Y	99.92	80'
3	P	99.08	80'
4A	Y	98.17	30'
			<u>240'</u>

4B	Y	98.17	50'
5	P	97.50	80'
6	Y	96.25	80'
7	P	95.00	30'
			<u>240'</u>

In tie  
septs

BY M EAUEN

DATE 03/2015

TYPICAL PROFILE

0-24 s/cu (VFr, ug-1)  
24-48 s/cu (Fr/Fi, s/h)  
Pa/cr 2 > 40"

THERE SHALL BE NO GRADING,  
 CUTTING, LOGGING OR OTHER SOIL  
 DISTURBANCE IN SEPTIC AREA

INSTALL AT 18-22"