Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

P	ROPERTY LOCATION: 133 SUNNYBROOK LN
ISSUED TO: H+H CONSTRUCTORS	SUBDIVISION OAKMONT LOT # 302
NEW REPAIR □ EXPANSION □	Site Improvements required prior to Construction Authorization Issuance:
Type of Structure: SFD (60×69')	
Proposed Wastewater System Type: 25% REDUCTION STORE	m,
Projected Daily Flow: GPD GPD	
Number of bedrooms:5	ax
Basement Yes No	
Pump Required: ☐Yes ➤ No ☐ May be required based on final loca	
Type of Water Supply: Community Public Well Distance	
Permit conditions:	☐ No expiration
Authorized State Agent::	Date: 10 25 18 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other p	ermits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This
site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Pe the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.	rmit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of
Constru	ction Authorization
(Requi	ired for Building Permit)
	958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance
KULED TO: Half Comession CTOOS	PROPERTY LOCATION: 133 SUNNYBEROUS LN
ISSUED TO: H-H CONSTRUCTORS	SUBDIVISION OAKMON: LOT # 302
Facility Type: SFD(60'~69') New	☐ Expansion ☐ Repair
	□ No
Type of Wastewater System** 25% REDUCTION	System (Initial) Wastewater Flow: 600 GPD
(See note below, if applicable \square)	
25% REDUCTION S	OKTEM (Renair)
Installation Requirements/Conditions Number of trenche	15 1 (nepan)
	ch trench <u>200</u> feet Trench Spacing: <u>9</u> Feet on Center
	installed on contour at a Soil Cover: inches
	Depth of: 18 inches (Maximum soil cover shall not exceed
	hall be level to +/-1/4" 36" above the trench bottom)
	and be level to 17-174 30 above the trench bottom
in all directions)	inches below pipe
Pump Requirements:ft. TDH vs GPM	• •
A	Aggregate Depth: inches above pipe
Conditions:	inches total
WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.	
**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.	
Owner/Legal Representative Signature:	Date:
Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Se	wage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH
	1 1
Authorized State Agent: RGM5	Date: 10 25 176
Construction Authorization Expiration Date: Lo 25 23	

Harnett County Department of Public Health Site Sketch

Authorized State Agent:

PROPERTY LOCATON: 133 SUMMY BROOK LN

SUBDIVISION DAKMONT LOT # 302

