

AMP'd Engineering, PLLC

Civil Engineer – Consulting Engineer – Land Development

PO Box 4580

Emerald Isle, NC 28594

(919) 795-9594 ✦ athan.parker@ampdengineering.com

Firm License Number P-1532

CERTIFICATION LETTER

May 13, 2019

**To: Mr. Oliver Tolksdorf,
REHS-Environmental Health Supervisor
Harnett County Health Department
307 W Cornelius Harnett Blvd
Lillington, NC 27546**

**Ref: Quail Hollow Lot 6 EOP
357 Deanne Ln
Coats, Harnett County, NC**

Dear Mr. Tolksdorf,

As a duly licensed registered Professional Engineer in the State of North Carolina, license number 43250, I have inspected the installation of the Engineered Option Permit of the LHD Referenced project SFD 1810-0036 on May 03, 2019. Thornton Plumbing the on-site wastewater contractor as permitted installed 4-75' 25% Reduction (Polystyrene) Type IIIg lines with 24" TB as designed and permitted, however, a pump tank has been added. The system appeared to be in the location permitted on the site plan by Pittman Soil Consulting.

If you have any questions, please feel free to give me a call (919) 795-9594 or email me (athan.parker@ampdengineering.com).

Sincerely,



010ATHAN M. PARKER, PE 04/US 04/AMP'D
ENGINEERING, PLLC
01000ATHAN.PARKER@AMPDENGINERING.COM
2016/05/13 17:03:21 -0400

Athan M Parker, PE
President
AMP'd Engineering, PLLC
Firm License No. P-1532



AMP

Attch: Owner's acceptance of the system, ATO Sheets and On-site Wastewater Contractors statement

AMP'd Engineering, PLLC
Civil Engineer – Consulting Engineer – Land Development

PO Box 4580
Emerald Isle, NC 28594
(919) 795-9594 ✦ athan.parker@ampdengineering.com
Firm License Number P-1532

ACCEPTANCE LETTER
May 06, 2019

To: WJH LLC (the "Owner")
3300 Battleground Ave, STE 230
Greensboro, NC 27410

Ref: Quail Hollow Lot 6 EOP
357 Deanne Ln
Coats, Harnett County, NC

Dear WJH,

As a duly licensed registered Professional Engineer in the State of North Carolina, license number 43250, I have inspected the installation of the Engineered Option Permit of the LHD Referenced project SFD 1810-0036 on May 03, 2019. Thornton Plumbing the on-site wastewater contractor as permitted installed 4-75' 25% Reduction (Polystyrene) Type IIIg lines with 24" TB as designed and permitted, however, a pump tank has been added. The system appeared to be in the location permitted on the site plan by Pittman Soil Consulting. This letter states the Owner's acceptance of the system from the Professional Engineer, Licensed Soil Scientist and the On-Site Wastewater Contractor as permitted with the Harnett County Health Department. Please sign this letter and have notarized on page 2 of 2.

If you have any questions, please feel free to give me a call (919) 795-9594 or email me (athan.parker@ampdengineering.com).

Sincerely,



ATHAN M. PARKER, PE, CIVIL, AMP'D
ENGINEERING, PLLC
athan.parker@ampdengineering.com
2019.05.06 10:52:14 -04'00'

Athan M Parker, PE
President
AMP'd Engineering, PLLC
Firm License No. P-1532



AMP

AMP'd Engineering, PLLC
Civil Engineer – Consulting Engineer – Land Development

Owner: Patrick Lamm [Signature] 5/6/19
Print Name Sign Name Date

North Carolina

Wake County

I, Tara Rabitz, a Notary Public for said County and State, do hereby certify that Patrick Lamm personally appeared before me this day and acknowledged the due execution of the page 1 of 2 "Acceptance Letter" from the PE.

Whitness my hand and official seal, this the 6 day of May, 2019.



Tara Rabitz

Notary Public

My commission expires 6/18, 2020.

PART 3: Authorization to Operate (ATO)

Except for date received, the Section below is to be completed by the Owner or by the PE designated to act as their legal representative for the EOP.

LHD USE ONLY: Initial submittal of request for ATO received: _____ by _____ Date Initials Date of Post-construction Conference: _____

The following items are included in this submittal for an Authorization to Operate under an EOP:

1. Signed and sealed copy of the Engineer's report that includes:
 - a. Signed and sealed evaluation of soil conditions and site features Yes No
 - b. Drawings, specifications, plans Yes No
 - c. Reports on special inspections and final inspection Yes No
 - d. Management Program manual Yes No
 - e. On-site Wastewater Contractor's signed statement Yes No
 - f. Signed and sealed statement pursuant to 15A NCAC 18A .1938(h) Yes No
2. Fee (as applicable) Yes No
3. Notarized letter documenting Owner's acceptance of the system from the PE Yes No

Attestation by the Owner or the PE for Authorization to Operate

I, ATHAN M. PARKER, PE hereby attest that all items indicated above have been provided to the
Print name of Owner or Professional Engineer

HARNETT County LHD and the system shall meet applicable federal, State, and local laws, regulations, rules and ordinances in accordance with G.S. 130A-336-1(e)(6).

	c:\ATHAN M PARKER PE c\US c\AMP'D ENGINEERING, PLLC c:\ATHAN M PARKER@AMPENGINEERING.COM 2018 05 13 17:03:46 -0400	<u>5/13/2019</u> <i>Date</i>
<i>Signature of Owner or Professional Engineer</i>		

This section for LHD Use Only.

LHD Review of required information for the ATO

INCOMPLETE
Based upon review of information submitted by the Owner or PE in the Section above, the following items are missing from the information required for an Authorization to Operate for an EOP: _____

Copies of this signed form were sent to the design PE and the Owner on _____ via _____
Date Email, FAX, USPS, Hand-delivered

<i>Print name of authorized Agent of the LHD</i>	<i>Signature of authorized Agent of the LHD</i>	<i>Date</i>
--	---	-------------

COMPLETE
Based upon review of information submitted by the Owner or PE in the Section above, this Authorization to Operate is hereby issued in accordance with G.S. 130A-336.1(m).

A copy of this complete NOI/ATO with tracking information was sent to the State on 5-15-19 via Email.
Date Email, FAX, USPS, Hand-delivered

<u>JAMES E. Mankin III</u>		<u>5-15-19</u>
<i>Print name of authorized Agent of the LHD</i>	<i>Signature of authorized Agent of the LHD</i>	<i>Date</i>

ISSUANCE OF CERTIFICATE OF OCCUPANCY: Once the LHD determines completeness based upon the PE submission, the owner may apply to the local permitting agency for permanent electrical service to a residence, place of business or place of public assembly pursuant to G.S. 130A-339.

EOP Tracking information

The LHD completes this form for each NOI/ATO submitted to their offices. The LHD updates this information and re-sends it throughout the process as appropriate. The Department will use this data to draft required legislative reports on implementation of the EOP.

Tracking information for Engineered Option Permits (Required)

County	HAZARD
LHD Reference Number	SFD 1810 - 0036
Permitting backlog as of date of NOI submittal (# days)	7-10 days
Number of days to process the NOI (# days)	13 Day
Number of days to process re-submitted NOI (# days or "NA")	
Facility type	SFD
Domestic, High Strength or IPWW	Domestic
Design Daily Flow	480
Residential or Commercial	Residential
System type (per Rule .1961)	III
Date of Post-construction conference	5-13-19
Date Authorization to Operate issued	5-15-19
Fee charged for EOP	250.00
Is fee sufficient to cover LHD costs?	YES
Date LHD notified of EOP malfunction	
Date LHD notified of Owner complaint	

PITTMAN SOIL CONSULTING


Owner: QUAIL HOLLOW
 Address: LOT 6
 Location: 357 DEANNE LANE

PROPERTY INFORMATION OBTAINED VIA
 HARNETT COUNTY MAP#99-19 DEED
 BOOK 1910 PG 0783

SOIL BORE (TYP)
0-12 SL GRL VFRL NEXP, 2.5Y 4/3
12-20 SL, GR, VFR, NEXP, 2.5Y 6/4
20-36 CL, SBK, FI, SS, SP, 10YR 5/8
36-48 CL, SBK, FI, SS, SP, 10YR 5/6, 7.5YR 5/8

Handwritten signature

Digitally signed by
 DN: cn=Athan M. Parker, o=Pittman Soil Consulting, PLLC, email=Athan.Parker@pittman-soil.com, c=US
 Reason: I am the issuer of this document
 Date: 2018.10.22



INITIAL
 4 BEDROOM
 LTAR .4
 4-75' 25% REDUCTION LINES
 24"TB
 >6" SOIL COVER REQUIRED OVER
 SYSTEM AND 5' BEYOND SYSTEM

REPAIR AREA
 4 BEDROOM
 LTAR .4
 4-75' 25% REDUCTION LINES
 24"TB
 >6" SOIL COVER REQUIRED OVER
 SYSTEM AND 5' BEYOND SYSTEM

SCALE 1"=40'



DEPARTMENT OF HEALTH AND HUMAN SERVICES
DIVISION OF PUBLIC HEALTH

ROY COOPER
GOVERNOR

MANDY COHEN, MD, MPH
SECRETARY

DANIEL STALEY
DIRECTOR

COMMON FORM FOR ENGINEERED OPTION PERMIT
See Instructions for Use in Appendix A

Except for "Date received", this Section to be completed by the Professional Engineer licensed in accordance with G.S. 89C

LHD USE ONLY: Initial submittal of this NOI received: _____ by _____
Date Initials

PART 1: Notice of Intent to Construct (NOI)

- New Expansion
 Repair – LHD Permit Number _____ Repair – EOP Permit Number _____

1. Facility Owner's name: (Owner, Company Name, Utility, Partnership, Individual, etc.): _____
WADE JURNEY HOMES - WJH LLC

Mailing address: 3300 BATTLEGROUNDAVE, STE 230 City: GREENSBORO State: NC Zip: 27410
Telephone number: 919-525-5856 E-mail Address: PLAMM@WADEJURNEYHOMES.COM

2. Professional Engineer (PE) name: ATHAN M PARKER, PE License number: 43250
Mailing address: PO BOX 4580 City: EMERALD ISLE State: NC Zip: 28594
Telephone number: 919-795-9594 E-mail Address: ATHAN.PARKER@AMPENGINEERING.COM

3. Licensed Soil Scientist (LSS) name: HAYWOOD PITTMAN, LLS License number: 1262
Mailing address: 1073-1 GREGORY FORK RD City: RICHLANDS State: NC Zip: 28574
Telephone number: 910-324-2892 E-mail Address: PITTMANSOIL@YAHOO.COM

4. Licensed Geologist (LG) (if applicable) name: _____ License Number: _____
Mailing address: _____ City: _____ State: _____ Zip: _____
Telephone number: _____ E-mail Address: _____

5. On-site Wastewater Contractor name: THORNTON PLUMBING, INC License number: 2534
3160-A VINSON RD. CLAYTON 27527
Mailing address: 1073-1 GREGORY FORK RD City: RICHLANDS State: NC Zip: 28574
919-550-4833 TPIPLANNER@GMAIL.COM
Telephone number: 910-324-2892 E-mail Address: PITTMANSOIL@YAHOO.COM

6. Proof of Errors and Omissions or other appropriate liability insurance for the following persons is attached that includes the name of the insurer, name of the insured and the effective dates of coverage:

- PE LSS LG On-site Wastewater Contractor

WWW.NCDHHS.GOV
TEL 919-707-5874 • FAX 919-845-3972
LOCATION: 5605 SIX FORKS RD • RALEIGH, NC 27609
MAILING ADDRESS: 1642 MAIL SERVICE CENTER • RALEIGH, NC 27699-1642
AN EQUAL OPPORTUNITY / AFFIRMATIVE ACTION EMPLOYER

3160-A Vinson Rd
Clayton, NC 27527
919-550-4833-Office
919-550-1637-Fax

Thornton's Plumbing, Inc.

Thornton's Footing, Hauling, and Septic, Inc.

May 7, 2019

Amp'd Engineering
PO Box 4580
Emerald Isle NC 28594

Re: Septic Install
Lot 6 Quail Hollow
357 Deann Lane, Coats
Wade Journey Homes

On May 2, 2019, TFH&S installed a 1000 gal septic and pump system with alarm and 300 ft of drain line.

There were 4 lines in total, 75 foot each of ez lay.

If you have any questions, please call.

Sincerely,



Andy Thornton
License #2534 Grade Level II
Thornton's Footing, Septic and Hauling
tplaner@gmail.com
919-550-4833
Fax: 919-550-1637

tplaner@gmail.com



THORPLU-01

RFURY

CERTIFICATE OF LIABILITY INSURANCE

DATE (MM/DD/YYYY)

4/24/2019

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AFFIRMATIVELY OR NEGATIVELY AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW. THIS CERTIFICATE OF INSURANCE DOES NOT CONSTITUTE A CONTRACT BETWEEN THE ISSUING INSURER(S), AUTHORIZED REPRESENTATIVE OR PRODUCER, AND THE CERTIFICATE HOLDER.

IMPORTANT: If the certificate holder is an ADDITIONAL INSURED, the policy(ies) must have ADDITIONAL INSURED provisions or be endorsed. If SUBROGATION IS WAIVED, subject to the terms and conditions of the policy, certain policies may require an endorsement. A statement on this certificate does not confer rights to the certificate holder in lieu of such endorsement(s).

PRODUCER: Pittman Insurance Group, LLC, 4011 Westchase Blvd. Suite 120, Raleigh, NC 27607. CONTACT NAME: Rhonda Fury, PHONE (A/C, No., Ext): (919) 741-5284, FAX (A/C, No.):, E-MAIL ADDRESS: rhonda@pittgroupplc.com. INSURER(S) AFFORDING COVERAGE: INSURER A: Builders Mutual Insurance Comp (NAIC # 10844), INSURER B: Accident Fund Insurance Co of (NAIC # 10166), INSURER C:, INSURER D:, INSURER E:, INSURER F:

COVERAGES CERTIFICATE NUMBER: REVISION NUMBER:

THIS IS TO CERTIFY THAT THE POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED. NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN, THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS AND CONDITIONS OF SUCH POLICIES. LIMITS SHOWN MAY HAVE BEEN REDUCED BY PAID CLAIMS.

Table with columns: INSR LTR, TYPE OF INSURANCE, ADDL INSD, SUBR WVD, POLICY NUMBER, POLICY EFF (MM/DD/YYYY), POLICY EXP (MM/DD/YYYY), LIMITS. Rows include Commercial General Liability, Automobile Liability, Umbrella Liab, and Workers Compensation and Employers' Liability.

DESCRIPTION OF OPERATIONS / LOCATIONS / VEHICLES (ACORD 101, Additional Remarks Schedule, may be attached if more space is required)

CERTIFICATE HOLDER: Amdp Engineering, PO Box 4580, Emerald Isle, NC 28594. CANCELLATION: SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, NOTICE WILL BE DELIVERED IN ACCORDANCE WITH THE POLICY PROVISIONS. AUTHORIZED REPRESENTATIVE: Rhonda Fury