



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918

http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: OLIVER TOLKSDORF
HARNETT CO ENVIRONMENTAL HEALTH
 307 CORNELIUS HARNETT BLVD
 Lillington, NC 27546

Name of System:
Red Door Homes
 14328 McDougald Rd.
 Sanford, NC

EIN: 566000306EH

Delivery: NC Courier

Harnett County

StarLiMS ID: **ES190314-0089** Date Collected: 03/13/2019 Time Collected: 10:00 By: Oliver Tolkسدorf
 Date Received: 03/14/2019 Time Received: 08:31 By: Susan Beasley

Sample Source: New Well Sampling Point: Sample port @ well
 Sample Type: Raw GPS No.
 Treatment: Well Permit No.

Comment: No well permit # given with sample.

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			03/14/2019
E. coli	Absent			03/14/2019

Report Date: 03/18/2019

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.