

HTE# _____

Harnett County Department of Public Health

29986

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: DUSTIN Blackwell PROPERTY LOCATION: on 1115 Buffalo Lakes
 NEW REPAIR EXPANSION SUBDIVISION: Buffalo Lakes LOT # 220,221
 Type of Structure: NEW SFD Demolition Site Improvements required prior to Construction Authorization Issuance: 222
 Proposed Wastewater System Type: EX SYSTEM
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: [Signature] Date: 11-14-18 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: DUSTIN Blackwell PROPERTY LOCATION: on 1115 Buffalo Lakes
 Facility Type: NEW SFD New Expansion Repair SUBDIVISION: Buffalo Lakes LOT # 220,221
 Basement? Yes No Basement Fixtures? Yes No Demolition to NEW SFD
 Type of Wastewater System** Existing (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Number of trenches 1
 Pump Tank Size 1000 gallons Exact length of each trench _____ feet Trench Spacing: _____ Feet on Center
NEW TANKS Trenches shall be installed on contour at a Soil Cover: _____ inches
 Maximum Trench Depth of: _____ inches (Maximum soil cover shall not exceed
 (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom)
 in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: _____ inches below pipe
 Conditions: NEW TANKS TO EXISTING SYSTEM _____ inches above pipe
 _____ inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 11-14-18
 Construction Authorization Expiration Date: 11-14-23

HTE# _____

Permit # 29986

Harnett County Department of Public Health Site Sketch

ISSUED TO: Dustin Blackwell PROPERTY LOCATOR: 52115 Buffalo Lake RD
 SUBDIVISION: Buffalo Lakes LOT # 220, 221
 Authorized State Agent: Jane E. Manhart Date: 11-14-18
222

* TANKS CAN BE
 PLACED ANYWHERE
 CONVENIENT AS LONG
 AS THEY MEET
 5' SETBACK
 OFF OF
 SFD

