

HTE# SFD1811-0008

Harnett County Department of Public Health

30284

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Milton Built Homes, LLC PROPERTY LOCATION: 742 River Road (SR 1418)
 NEW REPAIR EXPANSION SUBDIVISION: Raven Ridge LOT # 7
 Type of Structure: 4br 800'x80' SFD Site Improvements required prior to Construction Authorization Issuance: _____
 Proposed Wastewater System Type: 25% Reduction Sys.
 Projected Daily Flow: 480 GPD
 Number of bedrooms: 4 Number of Occupants: 8 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well NA feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: [Signature] Date: 11/28/2018 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Milton Built Homes, LLC PROPERTY LOCATION: 742 River Road (SR 1418)
 Facility Type: 4br 800'x80' SFD New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% Reduction Sys. (Initial) Wastewater Flow: 480 GPD
 (See note below, if applicable)
At-Grade 25% Reduction (Repair)

Installation Requirements/Conditions

Septic Tank Size 1250 gallons
 Pump Tank Size _____ gallons
 Number of trenches 4
 Exact length of each trench 90 feet
 Trenches shall be installed on contour at a
 Maximum Trench Depth of: 18 inches
 (Trench bottoms shall be level to +/-1/4"
 in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM
 Trench Spacing: 9 Feet on Center
 Soil Cover: 6 inches
 (Maximum soil cover shall not exceed
 36" above the trench bottom)
 Aggregate Depth: NA inches below pipe
NA inches above pipe
NA inches total
 Conditions: THREE(3) 115FT LINES PERMISSIBLE

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 11/28/2018
ANDREW CURRIN Construction Authorization Expiration Date: 11/28/2023

HTE# SFD 1811-0008

Permit # 30284

Harnett County Department of Public Health Site Sketch

ISSUED TO: Milton Built Homes, LLC PROPERTY LOCATION: 742 River Road (SN 1418)
SUBDIVISION: Raven Ridge LOT # 7

Authorized State Agent: ~~XXXXXXXXXXXX~~ Date: 11/28/2018
ANDRES CURTIN

