

# NORTH CAROLINA ENERGY CODE COMPLIANCE CERTIFICATE\*

(2012 NC Energy Code Section 401.3)

## Builder, Permit Holder, or Registered Design Professional

Print Name: BRANDON ZAVAR

Signature: *[Handwritten Signature]*

Property Address: 75 HODGES CHAPEL RD BENSON

Date: 7-17-19

## Building Air Leakage

Visually inspected according to 402.4.2.1 OR

Building Air Leakage Test Results

(Sec. 402.4.2.2)

ACH50 [Target: 5.0] or

CFM50/SFSA [Target: 0.30]

Name of Tester/Company: \_\_\_\_\_

Date: \_\_\_\_\_

Phone: \_\_\_\_\_

## Ducts:

Insulation: \_\_\_\_\_ R- 8

Total-Duct Leakage Test Result (Sect. 403.2.2) 4.4 CFM  
(CFM25 Total/100SF) [Target: 6]

Name of Tester/Company: MY HVAC GEN'S

Date: 7-17-19

Phone: 919-938-8202

## Certificate to be displayed permanently.

\*A permanent certificate shall be posted on or in the electrical distribution panel, inside the kitchen cabinet or other approved location. List primary type when there is more than one value for each component (i.e. certificate shall list the value covering the largest area). Required testing shall be performed and reported by the permit holder, a NC licensed general contractor, a NC licensed HVAC contractor, a NC licensed Home Inspector, a registered design professional, a certified BPI Envelope Professional or a certified HERS rater.

## Insulation Rating - List the value covering largest area to all that apply R-Value

Ceiling/Roof: \_\_\_\_\_ R- \_\_\_\_\_

Wall: \_\_\_\_\_ R- \_\_\_\_\_

Floor: \_\_\_\_\_ R- \_\_\_\_\_

Closed Crawl Space Wall: \_\_\_\_\_ R- \_\_\_\_\_

Closed Crawl Space: \_\_\_\_\_ R- \_\_\_\_\_

Slab: \_\_\_\_\_ R- \_\_\_\_\_

Basement Wall: \_\_\_\_\_ R- \_\_\_\_\_

## Fenestration:

U-Factor: \_\_\_\_\_

Solar Heat Gain Coefficient (SHGC): \_\_\_\_\_