

HTE# SFD1811-0025

Harnett County Department of Public Health

30351

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: LEE & KAREN KELLY PROPERTY LOCATION: PONDEROSA RO
 SUBDIVISION _____ LOT # _____
 NEW REPAIR EXPANSION
 Type of Structure: SFO(62'x46') Site Improvements required prior to Construction Authorization Issuance: _____
 Proposed Wastewater System Type: 25% REDUCTION SYSTEM
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: [Signature] REAS Date: 12/21/18 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: LEE & KAREN KELLY PROPERTY LOCATION: PONDEROSA RO
 SUBDIVISION _____ LOT # _____
 Facility Type: SFO(62'x46') New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable 25% REDUCTION SYS (Repair))

Installation Requirements/Conditions

Septic Tank Size <u>1000</u> gallons	Number of trenches <u>3</u>	Exact length of each trench <u>70</u> feet	Trench Spacing: <u>9</u> Feet on Center
Pump Tank Size <u>1000</u> gallons (IF NEEDED)	Trenches shall be installed on contour at a Maximum Trench Depth of: <u>12</u> inches (Trench bottoms shall be level to +/-1/4" in all directions)	Soil Cover: <u>6</u> inches (Maximum soil cover shall not exceed 36" above the trench bottom)	

Pump Requirements: _____ ft. TDH vs. _____ GPM _____ inches below pipe
 Aggregate Depth: _____ inches above pipe
 Conditions: _____ inches total

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] REAS Date: 12/21/18
 Construction Authorization Expiration Date: 12/21/23


HTE# SFDK11-0025

Permit # 30351

Harnett County Department of Public Health Site Sketch

ISSUED TO: LEG & KAREN KELLY PROPERTY LOCATOR: PONDEROSA RD
SUBDIVISION _____ LOT # _____

Authorized State Agent: ~~REGIS (OLIVER TOLKSDORF)~~ Date: 12/21/18




- * STUB PLUMBING AS SHALLOW AS POSSIBLE TO AVOID PUMP.
- * CALL WITH ANY QUESTION PRIOR TO INSTALLATION

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 3 BORN Design Flow (.1949): 12/19/18 Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5	0-12	GS	VFR NS/NP					
		12"	SBK C	FR S/P	10/12/2 @ 23"				US
2	LS 5-7	0-30"	GS	VFR NS/NP					
		30-48	SBK SCL	FR S/SP					PS .45
3		0-30"	GS	VFR NS/NP					
		30-48	SBK SCL	FR SS/SP					PS .45
4		0-28"	GS	VFR NS/NP					
		LP"	SBK SCL	FR SS/SP					PS .45
5		0-28"	GS	VFR NS/NP					S.6

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: 10/1/18 Others Present:
Available Space (.1945)	✓	✓	
System Type(s)	2 Pump 25% 45	45	
Site LTAR	45	45	



SITE PLAN APPROVAL
 DISTRICT RA-20R USE SFO
 #BEDROOMS 3
 11/27/18
 Zoning Administrator

578°28'02"E

435.5

ROBERT E.
 GULBRANDSON
 200 Pl. Cab. D, S. 157C
 578°28'03"E - 435.5

309.5 Feet
 Front

30 Feet
 From Side

House

30 Feet
 From Corner

300 Feet
 From Back

106 Feet
 From Side
 (Driveway)

DRIVEWAY
 101.08 Feet
 From Side

15 Feet
 From Front

N 78°52'W - 546.15

FUTURE

N 11°12'04"E

60

552°16'

51'

THE JOE MILLER TRACT