



Products				
PlotID	Length	Product	Plies	Net Qty
J-37	37' 10"	11-7/8" BCI® 4500s-1.8	1	11
J-14	14' 1 3/4"	11-7/8" BCI® 4500s-1.8	1	3
J-14	14' 0 1/4"	11-7/8" BCI® 4500s-1.8	1	12
J-14-2	14' 0 1/4"	11-7/8" BCI® 4500s-1.8	2	2
J-7	7' 9 1/4"	11-7/8" BCI® 4500s-1.8	1	1
RIM1	12' 0"	1" x 11-7/8" BC RIM BOARD OSB	1	13
BK1	2' 0"	11-7/8" BCI® 4500s-1.8	1	3



Boise Cascade Engineered Wood Products

Builders

www.BLDR.com

1135 Robeson St. Fayetteville, NC 28305 V (910) 485-1111 F (910) 485-6475

7601 BOEING DRIVE GREENSBORO, NC 27409 V: 336.884.5454

3189 NC HIGHWAY5 ABERDEEN NC 28315 V: 910.944.2516

This layout and associated materials list has been prepared based on project plans and/or information provided to Builders FirstSource (BFS). It

remains the responsibility of the builder, architect, designer, or other responsible persons to review this information to assure that it is appropriate, accurate, complete and complies with applicable building

1.) READ THE INSTALLATION GUIDE BEFORE
FRAMING.
2.) ALL WALL SHOWN ARE LOAD BEARING
UNLESS NOTES OTHERWISE WALLS NOT
SHOWN HAVE BEEN CONSIDERED NON-LOAD
BEARING
3.) UNLESS STATED OTHERWISE ALL CEILING &
ROOF LOADS BRACE DIRECTLY TO LOAD
BEARING WALLS SUPPORTED BY FOUNDATION
4.) CONTACT YOU LOCAL BUILDERS
FIRSTSOURCE LOCATION BEFORE MAKING
ANYALTERATION & ADJUSTIMENTS, FAILURE MAY
RESULT IN COSTLY REPAIRS

- GL H & H HOMES WAYFARE
CRAWL EWP PLACEMEN
Builders FirstSource, Central Ca
DRAWN BY:
LEE ATKINS:
SCALE: NTS

MINIMUM DESIGN DATA LIVE LOAD 40 PSF DEAD LOAD 10 PSF

TOTAL LOAD 50 PSF

STRESS DURATION = 100% DEFLECTION CRITERIA

L/480 (MINIMUM)

ARCHITECTUAL PLAN DATE 11-16-17 REVISED ARCH. PLAN DATE XX-XX-XX

SEALED PLAN DATE 12-27-17 Sheet 1 of 1

Minimum 1-3/4" bearing length Nails placed 1-1/2" minimum from end of BCI®Joist to limit splitting

8d each side of web

through flange at bearing-

(F52)