

WILBUR E. DEES, P.E., P.L.S.
CONSULTING ENGINEERING AND LAND SURVEYING
2927 MIDDLESEX ROAD
FAYETTEVILLE, N. C., 28306
PHONE / FAX (910) 425-1941
CELL (910) 624-4779

MARCH 6, 2019

HARNETTE COUNTY CENTRAL PERMITTING
P.O. BOX 65
LILLINGTON, NORTH CAROLINA 27546

RE: RESIDENCE
LOT #2
21 CASTELLO COURT
ANGIER, NORTH CAROLINA

TO WHOM IT MAY CONCERN:

THE ABOVE REFERENCED RESIDENCE IS BEING CONSTRUCTED UNDER YOUR BUILDING PERMIT # SFD1811-0012, ISSUED 1/23/2019.

BASED UPON MY SITE VISIT AND INSPECTION I FOUND APPROXIMATELY 25 LINEAR FEET OF FOOTING ON THE LEFT SIDE FOUNDATION WALL THAT WAS PREVIOUSLY ECCENTRICALLY CONSTRUCTED.

I AM ATTACHING A COPY OF MY DRAWING ENTITLED "CORRECTIVE FOOTING DESIGN".

I, HEREBY, CERTIFY THAT THIS CORRECTIVE WORK HAS BEEN COMPLETED, AS DRAWN. THE FOUNDATION FOOTING IS SAFE AND CAN ADEQUATELY SUPPORT ALL LOADS AS REQUIRED BY THE NORTH CAROLINA STATE RESIDENTIAL BUILDING CODE, 2018 EDITION.

SHOULD YOU HAVE ANY QUESTIONS DO NOT HESITATE TO CONTACT ME.

THANK YOU

