

HTE# 5571812-0019

Harnett County Department of Public Health

25314

PERMIT # 30317

Operation Permit

321412

New Installation Septic Tank Nitrification Line Repair Expansion

PROPERTY LOCATION: 199 Piney Field Rd. (Christen Light Rd.)

Name: (owner) Bateman Civil Survey Co. SUBDIVISION Masons Pointe LOT # 38

System Installer: Bateman Civil Survey Co. Registration # _____


Basement with plumbing: Garage Number of Bedrooms 4

Type of Water Supply: Community Public Well Distance from well NA feet

System Type: 25% Reduction Sys. IIIb Types V and VI Systems expire in 5 years.

(In accordance with Table V a) Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: As required by Rule .1961. Other: _____
Subsurface system operator required? Yes No
If yes, see attached sheet for additional operation conditions, maintenance and reporting.
- IV. Operation: _____
- V. Other: _____

D-Box Pump Alarm H2O Line PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: Conventional Other 4 chamber IIIg Septic Tank: 10000 gallons Pump Tank: 10000 gallons
 Subsurface No. of exact length 114, 114, width of depth of
 Drainage Field ditches 3 of each ditch 118 feet ditches 3 feet ditches 24 inches
 French Drain Required: _____ Linear feet

Authorized State Agent [Signature] Date 02/19/2019