

# A A TAKLA ENGINEERING, PLLC

Consulting. Design. Efficiency.

ANDY A. TAKLA, EI  
919-423-0470  
ANDYTAKLA@TAKLAENGR.COM  
Cert. #A-29014


ATEF A. TAKLA, PE  
919-358-1758  
ATEFTAKLA@TAKLAENGR.COM  
Lic. #14578

ALFRED A. TAKLA, EI  
919-332-7903  
ALFREDTAKLA@TAKLAENGR.COM  
Cert. #A-20939

NC Firm License No. P-1446  
PO Box 71298 Durham NC 27722

## FIELD REPORT

Date: 8/21/19  
Project: 8320 Nc Hwy42  
Location: Holly Springs, Nc  
Company: \_\_\_\_\_  
Care of: Jeff  
(919)799-8682



As requested, A. TAKLA VISITED THE SITE and observed the in-place concrete Footings for the House and Garage (moved House and Garage) and found Footings (sizes/depth and Bearing Capacity of supporting soils 2000 psf) are adequate to carry the loads, meet NCRC-2018

o.k To proceed with Foundation walls/piers.

**Limitations of Inspection** Services provided are in accordance with the standard of practice for structural engineering and within the limits imposed by scope, schedule and budget. The determinations contained in this report are based on conditions observed at the time of the evaluation. No guarantees or warranties, expressed or implied, under this Agreement or otherwise, shall be construed in connection with services provided. Sequencing, and means and methods of construction are considered beyond the scope of this report.