

www.harnett.org

Harnett County Government Complex 307 W. Cornelius Harnett Boulevard Lillington, NC 27546

ph: 910-893-7547

fax: 910-893-9371

February 27th, 2019

Bethany L. Scott 2701 Creek Trail Sanford, NC 27330

Re: Status of Permit Application-SFD1902-0024

Ms. Scott,

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (\$25.00 Fee incurred)
X 2. Use orange flags to mark house box.
3. Directions not clear to property (\$25.00 fee incurred)
4. Property needs all underbrush cleared prior to permitting
5. Driveway not shown on site plan
6. Backhoe pits required
X 7. Other- Area around house site needs to be cleared.

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,

Oliver Tolksdorf, R.E.H.S Environmental Health Supervisor Soil Scientist

Harnett County Department of Public Health

OT/kh

Copy: Central Permitting