

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 3-12-19
 Proposed Facility: 3 bedrooms Design Flow (.1949): 360 gal/day Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1		0-9"	GSL	VFr NS/Np					
		9-36"	SBKCL	Fr S/P					PS.3
2		0-12"	GSL	VFr NS/Np					
		12-32"	SBK SCL	Fr SS/SR					
		32-36"	SBK C2	Fr SS/SR					
		36-278"	SBK C	Fr S/P					PS.3

Description	Initial System	Repair System	Other Factors (.1946): - Site Classification (.1948): PS Evaluated By: CT Others Present: BO
Available Space (.1945)	✓	✓	
System Type(s)	RVMP	25' x 26'	
Site LTAR	3	3	